

**ENGINEERING STANDARDS FOR PUBLIC WORKS
CONSTRUCTION**



VOLUME 1

DESIGN AND PLANNING

April 2008

TABLE OF CONTENTS

CHAPTER 1 - GENERAL PLANNING, DESIGN, AND APPROVAL REQUIREMENTS

1.00	Requirements for Public Improvements	1-1
1.01	Precedence of Documents	1-2
1.02	Abbreviations and Definitions	1-3
1.03	Permits	1-6
1.04	General Requirements for Utility Extensions (Sanitary Sewer, Storm Sewer, Water)	1-6
1.05	Submittal Requirements.....	1-7
1.06	General Requirements for Engineering Plans.....	1-7
1.07	Requirements for Public Street Improvement Plans	1-9
1.08	Site Grading Plan	1-11
1.09	Erosion Control Plans	1-11
1.10	Requirements for Utility Plans (Water, Sanitary Sewer, Drainage)	1-11
1.11	Requirements for Supplemental Submittal Information	1-13
1.12	Review Procedure	1-15
1.13	As-Built Drawings	1-15
1.14	Professional Qualifications	1-16
1.15	Changes to Standards	1-16
1.16	Design Modifications Process	1-17
1.17	Errors and Omissions.....	1-17
1.18	Railroad Crossings	1-18
1.19	Penalties	1-18

TABLE OF CONTENTS

CHAPTER 2 - STREETS

2.00	Functional Classification	2-1
2.01	General Requirement for Layout	2-1
2.02	Access	2-2
2.03	Street Cross Sections	2-2
2.04	Number of Lanes.....	2-5
2.05	Design Speed	2-5
2.06	Dedications	2-5
2.07	Private Streets	2-7
2.08	Horizontal Alignment	2-8
2.09	Vertical Alignment	2-9
2.10	Transitions	2-12
2.11	Street Frontage Improvements.....	2-12
2.12	Street Ends	2-13
2.13	Medians.....	2-14
2.14	Intersections and Curb Returns.....	2-15
2.15	Sight Obstruction Requirements.....	2-16
2.16	Curb and Gutter - Types and Application.....	2-17
2.17	Survey Monuments	2-17
2.18	Concrete Sidewalks.....	2-18
2.19	Asphalt Sidewalks.....	2-19
2.20	Multi-Use Trail	2-19
2.21	Bikeways/Bike lanes.....	2-12
2.22	Driveways	2-20
2.23	Bridges	2-22
2.24	Landscaping in the Right-of-Way, Easements and Access Tracts	2-23
2.25	Mailboxes.....	2-24
2.26	Street Illumination	2-24
2.27	Traffic Control and Signing.....	2-26
2.28	Clear Zone and Appurtenances.....	2-27
2.29	Franchise Utilities	2-27
2.30	Safety Railing	2-27
2.31	Guard Rails	2-28
2.32	Surfacing Requirements.....	2-28
2.33	Utilities.....	2-31
2.34	Traffic Calming.....	2-31

TABLE OF CONTENTS

CHAPTER 2 - STREETS

(continued)

Tables

2.03A Street Widths.....	2-3
2.03B Alley Requirements	2-4
2.08A Design Speed / Center Line Radius - Minimums	2-8
2.09A Design Controls for Crest Vertical Curves Based on Stopping Sight Distance	2-11
2.09B Design Controls for Sag Vertical Curves Based on Stopping Sight Distance.....	2-11
2.09C Design Controls for Lighted Sag Vertical Curves 25 Miles per Hour.....	2-11
2.09D Design Controls for Lighted Sag Vertical Curves 15 Miles per Hour.....	2-12
2.14A Turning Radii (Feet) Edge of Pavement/Curb - Minimums	2-16
2.15A Corner Sight Distance.....	2-16

TABLE OF CONTENTS

CHAPTER 3 - STORM DRAINAGE

3.00	General Approval Requirements	3-1
3.01	Planning Criteria	3-1
3.02	General Design Requirements	3-2
3.03	Water Quality Standards	3-2
3.04	Design of Conveyance Facilities	3-3
3.05	Clearance / Other Utilities	3-6
3.06	Connections to Existing Systems.....	3-6
3.07	Design of Stormwater Inlets	3-7
3.08	Design of Stormwater Detention Facilities.....	3-7
3.09	Maintenance and ownership	3-8

TABLE OF CONTENTS

CHAPTER 4 - WASTEWATER COLLECTION

4.00	General Approval Requirements	4-1
4.01	Planning Criteria	4-1
4.02	General Design Standards	4-2
4.03	Main Lines	4-3
4.04	Side Sewers	4-3
4.05	Manholes	4-4
4.06	Pipe Class / Protection / Cover	4-5
4.07	Clearances / Other Utilities	4-6
4.08	Connections to Existing Systems	4-8
4.09	Fats, Oils, Grease Separation	4-9
4.10	Easements	4-10
4.11	Pump Stations	4-11
4.12	Grinder Pump System	4-13

TABLE OF CONTENTS

CHAPTER 5 - WATER

5.00	General Approval Requirements	5-1
5.01	Planning Criteria	5-1
5.02	General Design Standards.....	5-2
5.03	Valving.....	5-3
5.04	Fire Hydrants	5-4
5.05	Pipe Class / Protection / Cover	5-4
5.06	Clearances / Other Utilities.....	5-5
5.07	Slopes.....	5-6
5.08	Connections to Existing System	5-6
5.09	Easements	5-6
5.10	Services	5-6
5.11	Backflow Prevention.....	5-7
5.12	Reclaimed Water Systems	5-9

CHAPTER 1

GENERAL PLANNING, DESIGN, AND APPROVAL REQUIREMENTS

CHAPTER 1 - GENERAL PLANNING, DESIGN, AND APPROVAL REQUIREMENTS

1.00 Requirements For Public Improvements

A. General

The purpose of these standards is to define requirements for the design and construction of public improvements to serve new and future developments. These include street, bikeway, drainage, water, and sanitary sewer improvements as required by the development review process, City Ordinance, and other City policies adopted by the City Council or the Mayor. Where not governed by building or other codes, standards for site grading, erosion control, parking lot and driveway construction, and other infrastructure on private property shall also be governed by these standards for the purposes of design and inspection. No such work shall commence prior to City approval of the construction plans. Designs submitted shall be stamped by a registered Professional Engineer licensed to practice in the State of Washington.

All public improvements and private streets, parking lots, sidewalks, and driveways shall be designed and constructed according to the most recent edition of the ADA Standards for Accessible Design in such a manner as to be readily accessible to and usable by individuals with disabilities as per the requirements of the Americans with Disabilities Act of 1990. This includes providing curb ramps at intersections with pedestrian crosswalks to allow a smooth transition between street and sidewalk elevations.

B. Organization of Standards

These Standards are separated into three separate volumes; 1) Volume 1 - Design and Planning, 2) Volume 2 - Construction Specifications and Details, and 3) Volume 3 - Erosion Control Requirements.

C. Shortened Designation

These City of Ridgefield Engineering Standards for Public Works shall be cited routinely in the text as the "Standards".

D. Applicability

These Standards shall govern all new construction and upgrading of facilities both in the right-of-way and on-site for: transportation-related facilities; storm drainage facilities and stream channel improvements; sewer and water improvements; and park, recreation, and open-space facilities used by the public.

E. Requirements for Public Welfare

It is the purpose of these standards to provide for and promote the health, safety, and welfare of the general public, and not create or otherwise establish or designate any particular class or group of persons who will or should be especially protected or benefited by the terms of these standards.

The Standards established by this Chapter are intended to represent the minimum design standards. Compliance with these Standards does not relieve the designer of the responsibility to apply sound professional judgment to protect the health, safety, and welfare of the general public. Additionally, since these are minimum standards,

special site conditions and environmental constraints may require a greater level of protection than would normally be required under these Standards. The designer must apply these Standards bearing in mind these constraints.

F. Two-year Surety Bond Requirement

The developer is required to provide a maintenance bond for 20% of the full cost of construction for all public improvements for a period of two (2) years after acceptance of the project, which will not be released without written approval by the City. The developer is to provide from his contractor an itemized contractor's cost worksheet on the contractor's letter head and with contractor's signature. The contractor shall place the following note on the worksheet; "To the best of my knowledge the itemized quantities and cost included herein are an accurate account of the full cost of construction to be provided as required to meet the City's Maintenance Bond requirement".

G. Cost Estimate Requirements – Surety Bonds

The developer is to provide from his contractor an itemized contractor's cost worksheet on the contractor's letter head and with contractor's signature. The contractor shall place the following note on the worksheet; "*To the best of my knowledge the itemized quantities and cost included herein are an accurate account of the full cost of construction of the improvements as required by the City Engineer to be covered by the surety bond as required by the City of Ridgefield Municipal Code*". This requirement applies to all bonds and/or letters of credit.

H. Requirement for Street Utility Extension to Limits of Property

Public streets, bikeways/multi-purpose trails, water mains, sanitary sewer mains, and storm sewer mains shall be extended through and to the extremes of the property being developed for extension to future development as determined by the City. The developer shall not be reimbursed for utility extensions to the limits of the property being served. If a utility line must be oversized to serve the ultimate tributary area beyond the proposed development, the developer may request compensation for over sizing as authorized by Ridgefield Municipal Code. Such requests shall be in writing and shall be made to the City Engineer.

1.01 Precedence of Documents

If there is a conflict between approval documents, the document highest in precedence shall control. The precedence shall be:

- First: Permits from other agencies or jurisdictions, as may be required by law.
- Second: Facilities Review, Site Development Permit, and Planning Commission Conditions of Approval.
- Third: City of Ridgefield Engineering Standards for Public Works Construction.
- Fourth: City of Ridgefield Ordinances (Ridgefield Municipal Code).
- Fifth: Plans and details prepared by the design engineer and approved by the City.
- Sixth: American Public Works Association / Washington State Department of Transportation Standard Specifications, latest edition.
- Seventh: Reference specifications.

Supplemental written agreements and approved revisions to plans and specifications by the appropriate jurisdictions will take precedence over documents listed above. Detailed plans shall have precedence over general plans. In any event, the determination of the City Engineer shall be final.

1.02 Abbreviations and Definitions

AASHTO	American Association of State Highway and Transportation Officials
AC	Asphaltic Concrete
ACI	American Concrete Institute
ADA	Americans with Disabilities Act of 1990
ADT	Average Daily Traffic
ALTA	American Land Title Association Survey
ANSI	American National Standards Institute
APWA	American Public Works Association
ASTM	American Society for Testing and Materials
AWWA	American Water Works Association
Bicycle	A vehicle having two tandem wheels, propelled solely by human power
Bicycle Facilities	A general term denoting improvements and provisions which accommodate or encourage bicycling, including parking facilities, maps, signs, pathways, bike lanes, widened sidewalks, bikeways and shared roadways designated for bicycle use.
Bicycle Lane (Bike Lane)	A portion of a roadway which has been designated by striping, signing and pavement markings for the preferential or exclusive use of bicyclists
Bicycle Path (Off-Street Pathway)	A paved pathway physically separated from motorized vehicular traffic by an open space or barrier within an independent right-of-way
Bicycle Route (Bike Route)	A segment of a system of bikeways designated by the jurisdiction having authority with appropriate directional and informational markers, with or without a specific bicycle route number or as designated on a bicycle map, brochure or guidebook
Bikeway	Any road, path or way which in some manner is specifically designated as being open to bicycle travel, regardless of whether such facilities are designated for the exclusive use of bicycles or are to be shared with other transportation modes
CARV	Combination Air and Vacuum Release Valve
CBE	Crushed base equivalent (CBE) is the number that directly relates the traffic coefficient to the required number of inches of rock for street structural sections
CBR	California Bearing Ratio
City	City of Ridgefield with the Public Works Director as the lead contact person
City Engineer	City of Ridgefield's consulting or staff city engineer having authority specified in State law or City ordinances, or their designated representative
Contractor	The agent of the developer completing the construction activities

	associated with a given project
Contractor's Equipment	The phrase "Contractor's Equipment" shall include all items of materials or equipment remaining in the contractor's ownership and removed from the site upon completion of the project
Developer	The owner and/or his agent or contractor's responsible for a given project
Engineer	The City Engineer
Engineering Standards	The latest edition of the "City of Ridgefield Engineering Standards for Public Works Construction".
EPA	U.S. Environmental Protection Agency
Equipment	The machinery, accessories, appurtenances and manufactured articles to be furnished and/or installed under the Project
FEMA	Federal Emergency Management Agency
GPS	Global Positioning System
IE	Invert Elevation
Intersection	Refers to the area jointed by two (2) or more roads intersecting. For approaches of a continuous street at an acute curve or some other angle point with different street names
Item	A convenient subdivision of work under these specifications, as herein separately described
Material(s)	These words shall be construed to embrace machinery, manufactured articles, materials of construction (fabricated or otherwise) and any other classes of material to be furnished in connection with the project
MUTCD	Manual on Uniform Traffic Control Devices
NEC	National Electric Code with Washington amendments
Or Equal	Any manufactured article, material, method, or work which, in the opinion of the Engineer, is equally desirable or suitable for the purposes intended in these specifications and contract, as compared with similar articles specifically mentioned herein
OS and Y	Outside stem and yoke
OSHA	Occupational Safety and Health Administration
Parking Lot	Paved surfaces on private property intended for the movement and storage of 6 (six) or more vehicles
Plans	The plans shall mean all official drawings or reproductions of drawings made or to be made pertaining to the work provided for in the contract, or to any structure connected therewith
Project	The structure or improvement to be constructed in whole or in part through the performance of the contract
PRV	Pressure Reducing Valve
Sidewalk	The portion of a street designed for preferential or exclusive use by pedestrians
Specifications	The specifications shall mean the prescribed directions, requirements, explanations, terms and provisions pertaining to the various features of the work to be done, or manner and method of performance, and the manner and method of measurements and payments. They also include

Standards	directions, requirements, and explanations as set forth on the plans City of Ridgefield Engineering Standards for Public Works Construction, Volume 1, 2, and 3, latest edition
Standard Details	The latest edition of the City of Ridgefield's standard details for public works construction. Reduced copies are included in Appendix A of Volume 2 of these standards
Standard Specifications	The latest edition of the "Standard Specifications for Road, Bridge, and Municipal Construction" as published by the Washington State Department of Transportation and the American Public Works Association
Street	A public way which affords the principal means of access to abutting property
TCDH	Traffic Control Device Handbook
Traffic Coefficient	A number used in determining the structural section of a street
Trail	In the context of the Standards - "Trail" is synonymous with Multi-use Path (off-street pathway)
UBC	Uniform Building Code with Washington amendments
UFC	Uniform Fire Code with Washington amendments
UL	Underwriter's Laboratory
UMC	Uniform Mechanical Code with Washington amendments
UP	Uniform Plumbing Code with Washington amendments
WSDOT	The Washington State Department of Transportation
Wetlands	Those areas that are inundated or saturated by surface or ground water at a frequency and duration sufficient to support, and that under normal circumstances do support, a prevalence of vegetation typically adapted for life in saturated soil conditions. Wetlands generally include swamps, marshes, bogs, and similar areas. Identification and delineation of jurisdictional wetlands and wetland boundaries shall be done by a qualified biologist using applicable State and Federal guidelines.
Words and Phrases	Whenever the words, "as directed", "as required", "as permitted", or words of like effect are used, it shall be understood that the direction, requirement or permission of the Owner and Engineer is intended. The words, "sufficient", "necessary", "proper", and the like shall mean sufficient, necessary or proper in the judgment of the Owner and Engineer. The words, "approved", "acceptable", "satisfactory", or words of like import shall mean approved by or acceptable to the Owner and Engineer
Work	The work necessary to manufacture and deliver machinery, equipment and material and/or the furnishings of all labor, tools, material, equipment, construction equipment, working drawings, where required, and other, necessities for the construction or erection of the structures shown and called for in the plans, specifications and contract, and the act of constructing or erecting said structures complete.

1.03 Permits

Permits, approvals, or agreements are required by the City, and sometimes other jurisdictions, prior to initiating any construction or demolition work elements described within these Standards.

The majority of work covered under these Standards will require multiple permit authority review and approvals. Several types of permits and approvals require prior approval from the authority before a building or other substantial permit can be issued. Any questions regarding information about permits, approvals, and agreements should be directed to the City Clerk.

The following general categories describe the major permits, approvals, and agreements, along with issuing permit/code authority identified in parentheses:

A. Environmental Review

For most projects, including clearing and grading activity, an Environmental Checklist must be completed by the applicant and submitted along with plans, specifications, and other information when approval or permits are being requested for a project. The Community Development Director conducts the Environmental Review and makes a SEPA Threshold Determination for the City.

B. Building Permits

A Building Permit is required for all construction work including alteration, repairs and demolition. This includes retaining walls over 4 feet in height or with a surcharge loading. Demolition Permits for structures greater than four thousand square feet (4,000 sq. ft.) require the submittal of an Environmental Checklist.

C. Approvals and Other Permits

There are several other permits or approvals which may be required and referred to in these Standards: Developer Extension Agreements; plat and short plat approvals; and Certificate of Occupancy.

In addition, there are several other City approvals (land use) which may have been obtained prior to the above listed permits and which may affect the Standards as contained in this document.

1.04 General Requirements for Utility Extensions (Sanitary Sewer, Storm Sewer, Water)

A. When extension of the existing utility system for service is required, the developer shall submit site and improvement plans, utility design plans and design review and administration fees. The utility design plans shall be prepared and submitted as described in these Standards. Upon completion and approval by the City, plans and a pre-construction letter of requirements will be sent to the applicant. Requirements to be completed prior to construction will be noted in the pre-construction letter.

Upon completion of the pre-construction requirements and 48 hours notice, a pre-construction meeting shall be held with the Public Works Department at which time construction inspection will be scheduled. No public improvement construction shall commence prior to pre-construction meeting. After completion of construction and

submittal of required documents and fees, final acceptance will be given by the City at which time service will be available by permit.

- B. Easements for utility system shall be prepared by a surveyor or engineer licensed to practice in the State of Washington. The easement shall be reviewed and approved by the City prior to acceptance. All public utility easements shall be a minimum of 15-feet wide unless otherwise noted in these standards or required by the City Engineer. Width and location of private utility easements shall be determined by the City Engineer or the Building Official as appropriate.
- C. Upon final completion and final inspection approval, Public Works will issue a "Statement of Completion" to the developer indicating acceptance by the City for maintenance and operation of the developer extension.
- D. The developer shall have a surveyor licensed in the State of Washington provide final as-built elevations of manhole inverts and tops, gravity pipe grades, and utility locations. All elevations shall be from Clark County datum.

1.05 Submittal Requirements

A. General

- 1. Submittal requirements consist of design plans, grading plans (where required), erosion control plans (where required), drainage calculations, and other information as required. Letters of transmittal shall accompany all submittals. Resubmittals must include the previous set of "redlines" and a letter detailing responses to comments.
- 2. The Standard Specifications including their most recent revisions are hereby adopted and incorporated as part of this document by reference except as modified herein.

1.06 General Requirements for Engineering Plans

A. Design Plan Format

- 1. The plans shall be submitted on 22-inch x 34-inch or 24-inch x 36-inch sheets.
- 2. Title sheet to include project name, vicinity map, name and mailing address of developer/owner and engineering firm, general notes, notice to excavators, index, and space for city approval stamp (5 x 5-inch) or signature in the lower right quadrant. Vicinity maps shall show the location of the project in respect to the nearest major street intersection.
- 3. A north arrow shall be shown on each plan view sheet of the plans and adjacent to any other drawing which is not oriented the same as other drawings on the sheet.
- 4. Copies of Each Applicable City Standard Detail - Reference each City Standard Drawing by number on the Plan Sheets.
- 5. The scale shall be 1-inch = 2 feet, 3 feet, 4 feet, 5 feet, or 10 feet vertically and shall be 1-inch = 10 feet, 20 feet, 30 feet, 40 feet, or 50 feet horizontally for all drawings except structural details. Scale shall be shown with north arrow and within a title block.

6. Letter size shall not be smaller than 0.10 of an inch high.
 7. The location and elevation of a National Geodetic Survey, United States Geological Survey, Clark County, or City of Ridgefield bench mark shall be referenced on the plans. The datum shall be Clark County Datum NGVD 1929(47). No other datum shall be used without permission of the City Engineer. Temporary control bench marks and elevations shall also be shown on the plans.
 8. A title block shall appear on each sheet of the plan set and shall be placed in the lower right-hand corner of the sheet, across the bottom edge of the sheet, or across the right-hand edge of the sheet. The title block shall include the names of the project, the engineering firm, the owner, the sheet title, and the sheet number.
 9. The seal of the registered Washington Professional Engineer responsible for preparation of the plans shall appear on each sheet.
 10. The description and date of all revisions to the plans shall be shown on each sheet affected, and shall be approved and dated by the registered Professional Engineer of record as evidenced by an original signature or initial. The location of all revisions on each plan sheet shall be clearly identified through the use of "clouds", triangles or some other visible feature.
 11. Through use of standard drafting symbols, indicate the location and direction of view for all sections.
 12. The following statement shall appear on the cover sheet of all plans at a location immediately above or below the developer engineer's professional stamp - **"I hereby certify that these plans, and related design, were prepared in strict conformance with the City of Ridgefield Engineering Standards for Public Works Construction, as modified by Approved Modification, Variance, or Condition of Approval"**.
- B. Site Development Plans shall be organized as follows:
1. Title sheet.
 2. Approved preliminary plat (if it is a subdivision).
 3. Existing Conditions Plan - American Land Title Association (ALTA) survey be performed on and within one hundred (100) feet of the site and is to include, but not limited to the following; topography at 2 foot contour interval; watercourses (intermittent creek, streams, Rivers, etc.) and areas prone to flooding; FEMA designated floodplains and floodway; designated Shoreline areas; water bodies and known wetlands, wetland delineated boundaries; unstable slopes and landslide hazard areas; significant habitat areas; significant historic sites; Show layout and dimensions of all existing (parent) parcels; location of any existing building(s) on the site and use; location and width of existing easements for access, drainage, utilities, etc; name, location, width of existing right-of-way, centerline and right-of-way radius of existing roadway that abut the site; name location, width and surface material (e.g. gravel, asphalt or concrete) of roadway and easement (private and public); location and width of existing driveways and

those driveways across the street; location and width of existing pedestrian and bicycle facilities on and within 100 feet of the site; location and direction to nearest fire hydrant; location of existing sewage disposal systems and wells on site and within 100 feet of the site (as available from the city or health district)

4. Grading and erosion control plan with maximum contour intervals of 2 feet. The extent and limits of sensitive lands, as defined by the City Municipal Code shall be delineated on this sheet. This sheet shall also note the source of information, date of field work, and location of original document.
5. Street and storm sewer, showing existing and finished contours at 2-foot intervals. Storm sewer information may be included on water and sewer sheets where practical. In all cases, all proposed utilities shall be shown on each utility sheet, although notes and call-outs may be segregated per individual sheet.
6. Street and storm sewer profiles showing vertical curve information and stormwater invert and rim elevations.
7. Stormwater detention facility plan, sections, and details.
8. Sanitary sewer and water plan sheets, including service, valve, and fire hydrant locations. Sanitary sewer and water plan sheets may be separate if needed for clarity or where required by the City Engineer.
9. Water and sewer profiles showing locations of water air releases and invert and rim elevations of sanitary sewer pipes. Sanitary sewer and water profile sheets may be separate if needed for clarity or where required by the City Engineer.
10. Landscape plan including plants, trees, sidewalks, bikeways, retaining walls, irrigation, and lighting. Street light location, spacing, and type should be called out. Electrical service design may be provided as a separate submittal.
11. Signage and striping plan showing locations and types of street signage and striping. This plan may be included on other sheets provided that it is legible.

1.07 Requirements for Public Street Improvement Plans

- A. Plan Views shall show the following:
 1. Right-of-Way, property, tract, and easement lines (existing and proposed).
 2. Subdivision name, lot numbers, street names, and other identifying labels. Subdivision and street names are subject to review and approval of the City Community Development Director.
 3. Location and stationing of existing and proposed street center lines and curb faces.
 4. Horizontal alignment and curve data of street center lines and curb returns.
 5. Existing underground utilities and trees over 6-inches in diameter within and extending 50 feet beyond the construction limits.

6. Location of existing buildings, wells, septic tanks, drain fields, fuel tanks, and any other buried structures. An American Land Title Association (ALTA) survey shall be required for at least 100 feet surrounding any of the above items to remain.
 7. Match lines with sheet number references.
 8. Street stationing to be noted at a minimum of 100-foot intervals.
 9. Top of curb elevations along curb returns at quarter-delta's, and at 100-foot stations.
 10. Location of the low points of street grades and curb returns.
 11. Sidewalk locations. This shall include ramps, transitions in location or width, and relationship with driveways.
 12. Crown lines along portions of streets transitional from one typical section to another.
 13. Center line stationing of all intersecting streets.
 14. Location and description of existing survey monuments, including but not limited to: section corners, quarter corners, donation land claim corners, and City bench marks.
 15. Location of proposed street intersection monument boxes.
 16. FEMA designated 100-year flood plains and flood ways, or areas of flooding during a 100-year storm event.
 17. Wetland areas and storm water quality undisturbed corridors (buffer strips).
 18. Legend.
 19. Any additional information that the City deems necessary.
- B. Profile Views shall show the following:
1. Stationing, elevations, vertical curve data (including curve k factors), and slopes for center of streets or top of curbs. For off-set or superelevation cross-sections, both curbs shall be profiled. Where curbs are not to be constructed, center line of street and ditch inverts shall be shown.
 2. Original ground along the center line and if necessary at the edges of the right-of-way if grade differences are significant.
 3. Center line, top of curb or edge of pavement, and gutter flow lines of existing streets for a distance of at least three hundred (300) feet each way at intersections with proposed streets. For stub streets that may be extended in the future, the vertical alignment shall be designed for at least 300 feet beyond the scope of the proposed construction. At the discretion of the City Engineer, additional design information concerning the vertical and horizontal alignment of future street extensions may be required.
 4. Vertical alignment of streets, including existing center line monumentation.

5. The top of curb for all cul-de-sacs, eyebrows and curb returns.
6. Existing drainage facilities, including off-site facilities, upstream and downstream that affect the design (i.e., downstream restrictions that back water onto project site). In addition, base flood elevations shall be shown on the profile.
7. Profiles for ditch and creek flowlines shall extend a minimum of two hundred (200) feet beyond the project, both upstream and downstream. Typical cross sections at fifty (50) foot intervals shall also be submitted.
8. Designate structures using alpha or numeric labels on profiles to correspond to plan view notation.
9. All existing and proposed sanitary, water, storm lines and other utilities crossing the profile.

1.08 Site Grading Plan

The City of Ridgefield requires a site grading plan as part of the Application for any development that involves the excavation or fill of greater than fifty (50) cubic yards of material. Grading contours (existing & proposed) shall be at no more than 2 foot intervals, and shall extend off-site a minimum of 50 feet. This sheet shall also note source of information, date of field work, and location of original document, the calculated cut and fill quantities, location of stripping stockpile and any additional information that the city deems necessary.

A geotechnical evaluation report must be performed and referenced on the plan for site specific geotechnical recommendations. A copy of the report must accompany the plan for review and approval by the City Engineer. A modification to this requirement must be submitted to the City Engineer for approval.

All soil disturbing construction activity must adhere to the requirements of the City of Ridgefield Engineering Standards for Public Works Construction, Volume 3, Erosion Control Plans, and Technical Guidance Handbook. A detailed erosion control plan shall be shown in conjunction with the site grading plan.

1.09 Erosion Control Plans

Requirements for erosion control shall be listed in Volume 3 of the City's Engineering Standards.

1.10 Requirements for Utility Plans (Water, Sanitary Sewer, Drainage)

A. General Requirements

1. In plan view, location, stationing, materials, size, of all proposed utility lines (water, storm, sanitary). Location of all fire hydrants. Stationing shall be located in relationship to the street stationing at all manholes or other key locations.
2. Show all proposed manholes, inlets, and catch basins with all invert and top elevations.
3. For drainage plans, show existing drainage facilities, including off-site facilities, upstream and downstream that affect the design (i.e., downstream restrictions that

back water onto project site). In addition, base flood elevations shall be shown on the profile.

4. Designate structures using alpha or numeric labels on profiles to correspond to plan view notation. For water plans, each fitting/valve shall have attachment type listed (e.g. FL, MJ, FL x MJ, etc.).
 5. For water plans, provisions for cross-connection control must be clearly shown on the plans, including any retro-fitting of existing water service connections and existing auxiliary water supplies, conversions to City of Ridgefield water service that are required as a condition of development approval, upgrading of existing service connections by replacement of same, and any other cross connection control required by state and local rules and codes.
 6. All lengths and dimensions shall be horizontal distances, no slope distances on plans.
 7. Indicate type of pavement restoration required (if working in existing streets).
 8. Dimension existing and new utility locations from right-of-way line and/or property line. For water plans, drawings shall reference distance to nearest existing valve/hydrant from new point of connection to existing water main.
 9. Check that base map conforms to all requirements listed herein.
 10. On plans show existing manholes or give reference distances to existing manholes near project including manhole number and invert/rim elevations
 11. General construction notes must be included on first plan sheet. Remove notes that don't apply and add additional notes to the list if necessary.
 12. List vertical datum on plan and show bench mark to be used for vertical control during construction.
 13. The developer/contractor is responsible for sending a letter and preliminary plan to existing utility companies to inform them of new construction and requesting as-built information for incorporation into plans. At a minimum the following utilities shall be contacted:
 - Cable television
 - Natural gas
 - Power
 - Telephone
 14. Draft plans shall be sent to the above listed utilities to allow coordination of projects.
- B. Plan View
1. List pipe length, size and material along side of pipe, e.g. 150 l.f. - 8" PVC.
 2. Pipe length is to be based on horizontal distance between center of manholes.
 3. Indicate direction of flow with arrows on end of pipe entering manhole.

C. Profile View

1. List pipe length, size, material and slope to 4 decimal places (ft per ft), e.g. 150 l.f. - 8" PVC s=0.0125.
2. Slope based on invert elevation out of upstream manhole, invert elevation into downstream manhole, and horizontal distance between center of manholes.
3. Provide profiles for existing and proposed storm sewer and sanitary sewers. Profiles shall also be provided for new sewer force mains and new water mains.
4. Show all existing and proposed sanitary, water, storm lines and other utilities crossing the profile.
5. For drainage plans, profiles for ditch and creek flowlines shall extend a minimum of two hundred (200) feet beyond the project, both upstream and downstream. Typical cross sections at fifty (50) foot intervals shall also be submitted.

1.11 Requirements for Supplemental Submittal Information

- A. Drainage Calculations. Drainage calculations shall be presented in a clear, concise and complete manner and shall generally follow the format identified in the 1992 Stormwater Management Manual for the Puget Sound Basin. These calculations shall address all runoff into the drainage system; areas contributing flow to each inlet must be computed separately and each inlet with contributing area shall be designated and shown on an accompanying contour map work sheet. Initial time of concentration calculation with assumptions listed and charts or nomographs used shall be included with drainage calculations.
- B. Other information to be shown on the construction drawings or the other submittals include:
1. The design assumptions for each street (ex: traffic coefficient, R-value).
 2. The design elements such as:
 - Street classification;
 - Design speed;
 - Superelevation;
 - Average Daily Traffic (ADT) or Design Hourly Volume (DHV).
 3. Structural construction plans and the necessary calculations shall be submitted for proposed structures (ex: walls, box culverts, bridges).
 4. Any additional information that the City Engineer deems necessary to review the plans and assure compliance with design standards.
- C. Detail sheets. Detail sheets shall be provided showing all standard details.
- D. Standard Notes. Standard notes shall be included on the first sheet in the plan set. The following shall be the minimum required notes to be included:
1. *Construction shall conform to the requirements of the City of Ridgefield Engineering Standards, Volume 2 - Construction Specifications and Details, the latest edition of the APWA/WSDOT Standard Specification for Road, Bridge, and*

Municipal Construction, and the Land Use Conditions of Approval. It shall be the sole responsibility of the applicant and the professional civil engineer of record to correct any error, omission, or variation from the above requirements found in these plans.

2. Approval of plans for an individual grading permit by the City does not constitute an approval of any other construction (e.g. domestic water conveyance, sewer conveyance, gas, electrical, etc.).
3. Before any construction or development activity, a preconstruction meeting must be held between the City, the applicant, the applicants consulting engineer and construction representatives.
4. A copy of these approved plans must be on the job site whenever construction is in progress.
5. In accordance with Ridgefield Municipal Code Section 9.14.010, hours of permitted construction are limited to 7 a.m. to 10 p.m. Monday through Friday and 9 a.m. to 6 p.m. Saturday, Sunday and City observed holidays. Each violation shall be a civil noise infraction and shall result in a \$500 civil fine.
6. It shall be the Applicant's/Contractor's responsibility to obtain all construction easements and/or right of entries prior to construction work.
7. Vertical Datum shall be Clark County Datum NGVD 1929(47) unless otherwise approved by the City Engineer.
8. All utility trenches shall be backfilled and compacted to 90 percent maximum density as determined by AASHTO T-180.
9. All roadway subgrade within the roadway prism shall be backfilled and compacted to 90 percent maximum density as determined by AASHTO T-180, and the aggregate base rock compacted to 95 percent maximum density as determined by AASHTO T-180. The asphalt compaction shall be at least 91 percent based on a Rice theoretical maximum density, as determined in conformance with AASHTO T 209, as modified by WSDOT.
10. The base course and wearing course of asphalt concrete (AC) for streets shall be WSDOT Standard Hot Mix Asphalt Class ½-inch, PG 64-22.
11. Open cutting of existing roadways is not allowed unless specifically approved by the City and noted on these approved plans. Any open cut shall be restored in accordance with the standard trench restoration details and notes.
12. The Contractor shall be responsible for providing adequate safeguards, safety devices, protective equipment, flaggers, and any other needed actions to protect the life, health and safety of the public, and to protect property in connection with the performance of work covered by the contractor. Any work within the traveled right-of-way that may interrupt traffic flow shall require at least one flagger for each lane of traffic affected. Section 1-07.23 "Traffic Control" of the WSDOT Standard Specifications shall apply in its entirety.

13. Upon discovery of potential or known archaeological resources at the subject site prior to or during on-site construction, the developer, contractor, and/or any other parties involved in construction shall immediately cease all on-site construction in accordance with RCW 27.53.060.

1.12 Review Procedure

Three (3) sets, or as directed by the City Engineer, of complete draft plans shall be submitted for review. Plans shall be complete and shall be stamped and signed by the developer's engineer. Three (3) copies of supporting information and documentation, such as drainage and water system calculations, shall also be submitted.

Upon completion of the detailed review by the City, the City will return one (1) set of draft plans with "Red Line" comments. After the developer's engineer has completed all revisions, three (3) revised plans and the original "Red Line" plans shall be returned to the City on each iteration of plan review.

Following approval of draft plans and calculations by the City Engineer, and following the signing of approval of the photographically reproduced 4-mil mylar cover sheet by the Clark County Fire District, the developer's engineer will submit two (2) original final plan sets. The cover sheet only of one (1) of the plan sets shall be photographically reproduced 4-mil mylar for the City Engineer's approval signature. Following obtaining the approval signatures, the City will notify the developer's engineer that the original mylar plan have been signed and are ready for release.

Plan review priority will be given to plans submitted for final review. This plan review and approval is valid for two (2) years from the date of plan review fee payment. Extensions to the permit may be made by the City Engineer in extenuating circumstances, upon request by the Developer.

Plan approval means that the plans have been reviewed for reasonableness and compliance with minimum City specifications and standards. This approval does not supersede those standards and specifications, unless specifically varied by the City. Plan approval does not relieve the developer's engineer from responsibility for errors, omissions or deficiencies in the plans.

1.13 As-Built Drawings

Following completion of construction, the developer's engineer shall submit one (1) complete set of mylar as-built drawings and one (1) complete set of bond (paper) as-built drawings. As-built drawings shall contain any and all revisions to the previously approved construction plans, and shall be accompanied by a completion certification letter from the developer's engineer. As-built information shall be obtained and provided to the developer's engineer by a surveyor licensed in the State of Washington. The as-built drawings shall include all the approved plan information plus the revised data as obtained by the as-built survey and shall include the landscaping & irrigation and lighting & electrical plan sets. The design information shall be lined out where revised by the addition of the as built data. All as built information shall be made electronically; no

hand written information will be accepted. Additional as built information may be required by the City Engineer.

Each sheet of the as-constructed drawings, including the cover sheet, shall be stamped "As-Built" or "Record Drawing", and signed and dated by the developer's engineer. This signature constitutes a certification that the public improvements, grading, and other elements of the engineered drawings have been completed in accordance with the City approved plans and to the standards of the City.

As-builts shall be black India ink on originals or reverse reading, fixed-line, photographically reproduced 4-mil mylar, 22-inch x 34-inch or 24-inch x 36-inch in size and to engineering scale. All sheets of the construction plan shall be as-built. Sepia mylars or vellums will not be accepted. The City also shall receive all sheets in electronic form as a "PDF" file and AutoCAD DWG file on CD-rom. Electronic copies (PDF) of the as-built drawings shall be exact duplicates of the Mylar copy.

Submission of as-built drawings shall be made prior to final inspection of a completed project.

1.14 Professional Qualifications

Professionals in the technical fields of Civil Engineering, Electrical Engineering, Geotechnical Engineering, Landscape Architecture, Soils Engineering, Structural Engineering, and Surveying who prepare or are responsible for the preparation of drawings, plans, specifications, technical reports, etc. for the process of obtaining required permits/approvals shall be currently licensed or registered in the State of Washington and qualified by both experience and educational background in the specific technical areas as warranted by the specific needs of the proposed development project.

1.15 Changes to Standards

From time to time changes may be needed to add, delete, or modify the provisions of these standards. The City Engineer may propose changes to these Standards and upon approval of the Public Works Director, they shall become effective and shall be incorporated into the existing provisions. Comprehensive revisions to the Standards shall be proposed by the City Engineer and Public Works Director and adopted by the City Council.

1.16 Design Modifications Process

A. Submittal

Requests to modify City Standards shall be submitted in writing by the developer's engineer, to the City Engineer. This written request shall state the desired modification(s), the reason(s) for the request(s) and a comparison between the specification(s), standard(s), and the modification(s).

Any request for modification or variance of City Standards should be documented with reference to nationally accepted specifications/standards.

B. Review

The request to modify shall be reviewed by the City Engineer, who shall consult the appropriate review authorities and make one of the following decisions:

1. Approve as is,
2. approve with changes,
3. or deny with an explanation.

The modification, if approved, is for project specific use. Approval of a request shall not constitute a precedent.

C. Appeal

The applicant may appeal the City Engineer's decision to the City Council.

D. Criteria for Modification of Standards

The City Engineer may grant a modification to the adopted specifications or standards when any one of the following conditions are met:

1. The specification or standard does not apply in the particular application.
2. Topography, right-of-way, or other geographic conditions impose an economic hardship on the applicant and an equivalent alternative which can accomplish the same design is available that does not compromise public safety or accessibility for the disabled.
3. A change to a specification or standard is required to address a specific design or construction problem which if not enacted will result in an undue hardship.

1.17 Errors and Omissions

At the discretion of the City, any significant errors or omissions in the approved plans or information used as a basis for such approvals may constitute grounds for withdrawal of any approvals and/or stoppage of any or all of the permitted work. It shall be the responsibility of the developer to show cause why such work should continue, and make such changes in plans that may be required by the City before the plans are reapproved.

1.18 Railroad Crossings

A. General

100

Crossings of railroad rights-of-way shall be done in a manner which conforms with the requirements of the railroad having jurisdiction. If any bonds and/or certificates of insurance protection are required, they shall be furnished by the Contractor or Owner to the railroad company with the City as an additionally-named insured.

B. Permits or Easements

Crossing agreements, permits, and/or easements for such crossings will be obtained by the applicant and all the terms of such permits or easements shall be met by the Owner and Contractor.

1.19 Penalties

Failure to comply with these standards will be cause for withholding or withdrawing approval of plans or plats, forfeiture of bond, withholding Temporary and/or Final Certificate of Occupancy, and/or other penalties as provided by law.

CHAPTER 2

STREETS

CHAPTER 2 - STREETS

2.00 Functional Classification

The functional classification of existing and proposed roads is established by the City on an individual basis using the existing land use and existing operational characteristics. Ridgefield classifies roads and streets as follows:

- A. Major Arterials. These facilities are the supporting elements of both the principal routes and collector systems. Major arterials, in combination with principal routes, are intended to provide a high level of mobility for travel within the region. All trips from one sub-area through an adjacent sub-area traveling to other points in the region should occur on a major arterial or principal route.
- B. Minor Arterials. The minor arterial system complements and supports the principal and major systems, but is primarily oriented toward travel within and between adjacent sub-areas. An adequate minor arterial system is needed to ensure that these movements do not occur on principal routes or major arterials. These facilities provide connections to major activity centers and provide access from the principal and major arterial systems into each sub-area.
- C. Collectors. The collector system is deployed nearly entirely within sub-regions to provide mobility between communities and neighborhoods or from neighborhoods to the minor and major arterial systems. An adequate collector system is needed to ensure these movements do not occur on principal routes or major arterials. Emphasis is on collection and distribution of trips within an arterial grid and direct access from parcels is limited to the extent possible... Subcategories of collectors include standard collectors, scenic collectors, and industrial/commercial collectors.
- D. Local Streets. The local street system is used throughout developed areas to provide for local circulation and direct land access. It provides mobility within neighborhoods and other homogenous land uses, and comprises the largest percentage of total street mileage. In general, local traffic should not occur on major arterials and principal routes. Subcategories of local streets include local access, residential local, and industrial local.

2.01 General Requirement for Layout

The City's Comprehensive Plan states that future street construction will encourage connectivity. Street sizing for arterials and collectors assumes that the transportation system will encourage non-motorized transportation. To meet the planning objectives, the City has established a standard of at least eight (8) through streets per mile to allow neighborhood trips on a smaller scale. The City's objective is to impose a maximum spacing for new streets of five hundred (500) feet (a 500-foot maximum grid) within all new developments and to the limits of the entire parcel of property being developed. Layout of new development will provide the capability of extending future streets through adjacent parcels by having streets proposed for that development extended to the limits of the property and located so as to provide a spacing of 500 feet. Where this requirement is not feasible due to topography, a 10-foot wide paved bikeway\multipurpose trail can be substituted for the street if approved by the City. The bikeway\multipurpose trail,

located in a dedicated 30-foot easement for pedestrians and bicyclists, shall be extended to the limits of the property. Said bikeway\multipurpose trail shall follow the general grid pattern of the street layout (500 foot grid) and shall extend from the ends of dead-end streets where said dead-end street are not capable of being extended to the limits of the property due to topographic constraints. To meet the through street planning objectives, streets or bikeway\multipurpose trails shall be designed and constructed to extend to the limits of the property with the all costs borne by the developer of the property without reimbursement by the City.

2.02 Access

Access to public streets shall conform to the requirements listed herein. The City Engineer and the Public Work Director` shall have the authority to limit access and designate access locations on public streets under the jurisdiction of the City. Access to streets and highways under Clark County or State of Washington jurisdiction must be formally approved by those entities at the applicant's initiative and expense.

2.03 Street Cross Sections

- A. Table 2.03A is a summary of street cross section standards by the functional classification of the road. It should be noted that public utility easements beyond the right-of-way are typically required.

All new roadways shall be provided with a centerline crown with an allowable cross slope between 2% and 4%.

- B. Alleys. Alleys may be used to provide alternative access to lots. Table 2.03B provides alley requirements.

Alleys must be provided with a gutter or other means for collecting storm water runoff, and must meet the requirement of Section 503 of the International Fire Code (IFC)

Table 2.03A – Street Cross Sections

Parameter	Roadway Classification									
	Major Arterial	Minor Arterial	Downtown Minor Arterial	Standard Collector	Industrial/ Commercial Collector	Scenic Collector	Industrial Local	Residential Access	Residential Local A	Residential Local B
Right-of-Way	100	80	60	70	70	60	60	60	48	48
Total Pavement	74	46	40	46	46	24	42	36	28	28
Number of Drive Lanes	4	2	2	2	2	2	2	2	2	1
Width of Drive Lanes	12	12	12	10	12	12	14	10	10	12
Number of Turn Lanes/Median	1	1	0	0	1	0	1	0	0	0
Width of Turn Lanes	14	12	0	0	12	0	14	0	0	0
Number of Parking Lanes	0	0	2	2	0	0	0	2	1	2
Width of Parking Lane	0	0	8	8	0	0	0	8	8	8
Number of Bike Lanes	2	2	0	2	2	0	0	0	0	0
Width of Bike Lane	6	5	0	5	5	0	0	0	0	0
Number of Sidewalks	2	2	2	2	2	1	2	2	2	2
Width of Sidewalks	6	6	10	6	6	6	6	5	5	5
Number of Planter Strips	2	2	0	2	0	0	0	2	2	2
Width of Planter Strip (incl. curb)	7	11	0	6	0	0	0	7	5	5
Design Volume	24000	24000	12000	10000	10000	5000	2000	2000	500	250
Design Speed	45	45	25	35	35	35	25	25	25	25

Notes:

1. Sidewalk for Scenic Collector may be a detached path.
2. Residential Local B allows parking in one of the travel lanes.
3. S.R. 501 (Pioneer Street) is a State Highway and has separate standards. Major Arterial data in Table 2.03A does not apply.

Table 2.03B – Alley Requirements

	Short Alley¹	Long Alley¹
Function and Limitations	Alleys provide direct access to adjoining lots. They reduce the number of required curb cuts along public streets and improve the appearance and human scale of streetscapes (i.e., by reducing the amount of parking and parking garages oriented to the street). Short alleys are appropriate in low-density residential zones with minimal traffic generation and relatively short blocks (i.e. 200-400 feet). Short alleys may function as through-travel lanes terminating at public streets or parking courts (e.g. hammer-head terminus) only. When used as parking courts, alleys may not exceed 150 feet in length. Alleys may not be used in a "grid" type pattern.	Long alleys are appropriate for low-density residential development on longer blocks (i.e. 400-500 feet), and medium and high-density residential development when parking bays are provided. They may also provide access to commercial development. Long alleys may function as through-travel lanes terminating at public streets or parking courts (e.g. hammer-head terminus) only. When used as parking courts for more than four vehicles, alleys may not exceed 150 feet in length (i.e. from street access to parking bay). Alleys may not be used in a "grid" type pattern.
Access	Full access to adjoining lots provided that all lots having alley access front on a public or private street and provided that alleys are a permanent secondary not primary means of access to the lot, unless otherwise authorized by the Planning Director, Public Works Director, or hearings examiner.	Full access to adjoining lots provided that all lots having alley access front on a public or private street and provided that alleys are a permanent secondary not primary means of access to the lot, unless otherwise authorized by the Planning Director, Public Works Director, or hearings examiner.
Average Daily Trips	Under 150+/-	Under 500+/-
A. Right-of-Way or Easement	12 feet minimum 15 feet maximum	20 feet minimum and maximum except as wider sections may be approved as necessary for parking courts.
B. Pavement Width	10 feet (1-foot clear zone on both sides)	18 feet (1-foot clear zone on both sides)
D. Building Setbacks and Clear Vision Zones	Please refer to zoning chapters.	Please refer to zoning chapters.
E. Lighting	Low-profile, security lighting shall be required with new development.	Low-profile, security lighting shall be required with new development.
<p>1 The city engineer shall determine which alley standard is used.</p> <p>2 Additional right-of-way or easement area may be required when parking bays are incorporated into the streetscape, or when slopes/physical conditions require additional right-of-way. Right-of-way requirements shall be determined through the subdivision and site design review permit process.</p> <p>3 Alleys will be considered public streets to be owned and maintained by the City unless otherwise stated in the Conditions of Approval in the final land use approval or on the Final Plat. Must meet IFC Section 503 if determined by the Fire District to be a Fire Accessible Roads.</p>		

2.04 Number of Lanes

The number of lanes for each class of road shall be as directed by the City Engineer. Additional lanes may be required at intersections in excess of the road sections shown in Table 2.03A.

Right-of-way may be needed in addition to that shown in Table 2.03A to accommodate the increased number of lanes at intersections.

2.05 Design Speed

The minimum design speed for each road classification shall be as shown in Table 2.03A or as otherwise determined by the City Engineer. The design speed for arterials may be reduced due to unique topographic or traffic conditions if approved by the City Engineer. The design speed may also be temporarily reduced in construction zones, as determined by the City Engineer.

2.06 Dedications

- A. Right-of-Way shall be deeded for streets and other improvements as required per Table 2.03A to accommodate motorized and non-motorized transportation, landscaping, utility and buffer requirements. Some reduction in the minimum right-of-way requirement may be granted by the City Engineer where it can be demonstrated that sufficient area has been provided for all functions within the right-of-way and/or alternate locations. Conveyance shall be fee simple using a statutory warranty deed.
- B. Easements for all public systems shall be provided as required. Specific requirements for sewer, water, and storm drainage easements are detailed in the relevant chapters. Particular design features of a road may necessitate slope, wall or drainage easements. Such easements may be required by the City Engineer in conjunction with dedication or acquisition of right-of-way and other standard easements (temporary construction, right of entry, sidewalk, pedestrian, street lighting, and traffic control devices, etc.).
- C. Special Access Easements or Tracts.
Where it is necessary to facilitate pedestrian circulation between neighborhoods, schools, shopping or other activity centers, public access easements or tracts shall be dedicated.

Improvements to the easement shall include a sidewalk or trail consistent with other non-motorized facilities in the area. Fences shall be constructed along access easements in residential areas where buildings will be located nearer than fifty (50) feet to the edge of the easement. Diverters or bollards shall be installed at the direction of the City Engineer.

- D. All subdivisions and short subdivisions (short plats) will be required to deed additional right-of-way, as a condition of approval of the subdivision, where the existing right-of-way for a public street is not adequate to incorporate necessary frontage improvements for public safety and provide compatibility with area's circulation system and to meet the City's most recent Comprehensive Plan and Transportation Capital Facilities Plan.

All short subdivisions (short plats) will be required to deed additional right-of-way, as a condition of approval of the short plat, under one or more of the following conditions:

1. The short plat abuts an existing substandard public street and the additional right-of-way is necessary to incorporate future frontage improvements necessary for public safety, or
 2. Additional right-of-way is needed to provide right-of-way for the extension of existing public street improvements necessary for public safety, or
 3. Additional right-of-way is needed to provide future street improvements necessary for public safety for planned new public streets.
- E. It is within the authority of the City Engineer to refuse to approve or sign any land partition, partition plat, or subdivision plat that the owner or developer has not obtained the necessary right-of-way and easements for the public infrastructure to serve the proposed and affected existing lots. Such approval may be withheld until it can be verified that the location and width of proposed rights of way and easements are adequate for the required infrastructure.
- F. Easements are subject to the approval of the City Attorney prior to recording. Variation from the City standard form of conveyance shall be allowed only when extraordinary circumstances warrant, as determined by the City Engineer and City Attorney.
- G. Bikeway\Multipurpose Trail. Where bikeway\multipurpose trails are constructed, a 30-foot dedicated right-of-way shall be granted to the City.
- H. Easement Widths
1. Pedestrian pathway access easements or tracts shall be a minimum of ten (10) feet wide. If the easement is over one-hundred and fifty (150) feet in length but less than three-hundred (300) feet, the width shall be fifteen (15) feet; if over three-hundred (300) feet in length, the width shall be twenty (20) feet. Structure setbacks shall be a minimum of fifteen (15) feet from the edge of the easement or tract.
 2. In residential subdivisions or residential short subdivisions, panhandle access (flag) driveway easement may be allowed for access to a maximum of two (2) lots and must have a minimum easement width of twenty (20) feet and shall not exceed one hundred (100) feet in length unless approved by the City Engineer. A greater width may be required to accommodate grading, utility requirements, or the Fire District.
 3. In commercial subdivisions or commercial short subdivisions, a private roadway easement or panhandle (flag) access easement may be allowed for access to a maximum of two (2) lots and must have a minimum easement width of thirty (30) feet. A greater width may be required to accommodate grading, utility requirements, or the Fire District.

- I. All recording costs for easements created by private development shall be borne by the developer unless specifically agreed to by the City.

2.07 Private Streets

- A. **Criteria for Authorization.** It is the City of Ridgefield's policy to discourage private streets and to only permit them under unusual circumstances as applied with small infill developments of a maximum of eight (8) lots. Where private streets are permitted, they will only be under the following conditions:
 1. Covenants have been approved, recorded, and verified with the City which provide for maintenance of the private streets and associated parking areas by owners in the development, and
 2. Provision is made for the streets to be open at all times for emergency and public service vehicles, and
 3. The private streets will not obstruct public street circulation, and
 4. A private street shall ultimately serve a maximum of eight (8) residential lots. Any access serving three or more dwelling units shall be either a public or private street.
 5. The private street has been approved by the Fire District
 6. At least one of the following conditions exist:
 - a) The roadways serving commercial or industrial facilities where no circulation continuity is necessary.
 - b) The City Engineer determines that no other access is available and the private road is adequate.
- B. **Notice.** A statement is required on the face of any plat or short plat containing a private road that reads: "The City of Ridgefield has no responsibility to improve or maintain the private roads and it shall be the sole responsibility of the property owners to improve or maintain the private roads providing access to the property contained within and described in this plat". The developer or benefiting property owners shall submit a private road maintenance agreement for review by the City Engineer. The private road maintenance agreement shall be recorded with the plat.
- C. **Easements.** The minimum easement or tract width for a private road shall be thirty (30) feet.
- D. **Design Requirements.** Private streets shall conform to public street construction standards with the exceptions noted herein.
 1. Private streets shall be improved with a minimum road section of 3-inches of asphalt concrete over 8 inches of crushed rock. The minimum paved width shall be twenty (20) feet (curb face to curb face). At the discretion of the City engineer, the private roadway improvement is to include curb and gutter, and sidewalk on one side of the roadway (see F below).

2. The maximum grade for private roadways shall be eighteen percent (18%). Roadways that must be used to provide access to fire vehicles, as determined by the Fire District, shall be a maximum of twelve percent (12%).
 3. Drainage improvement requirements shall be as specified in Chapter 3 of these Standards.
 4. Utility requirements shall be per this chapter, and Chapters 4 & 5 of these Standards.
 5. Street illumination is required at the intersection of a private street and a public street. No street lighting is required on private streets.
- E. Acceptance as Public Streets. Acceptance of private streets as public streets will be considered if the street meets all applicable public street standards contained herein.
- F. The City encourages the use of “Sustainable Street” concepts and also Low Impact Development (LID) concepts and techniques in proposed private street designs.

2.08 Horizontal Alignment

Street alignments shall meet the following requirements:

- Center line alignment of improvements should be parallel to the center line of the right-of-way.
- Center line of a proposed street extension shall be aligned with the existing street center line.
- Horizontal curves in alignments shall meet the minimum radius requirements as shown in Table 2.08A or the low speed curve table at the end of this section for residential local streets.
- Except on residential local streets, reversing horizontal curves shall be separated by no less than 50 feet of tangent. On arterials, the separation shall be no less than 100 feet.

Table 2.08A - Design Speed / Center Line Radius – Minimums

Design Speed (mph)	Arterials Streets and Commercial/Industrial Collectors	
	Minimum Centerline Radius (ft)	
	Crown	(e) 6%
30	430'	273'
35	610'	380'
40	860'	509'
45	1,080'	656'

Collectors and Residential Streets

Design Speed (mph)	Minimum Centerline Radius (ft)			
	Crown	(e) 2%	(e) 4%	(e) 6%
25	180'	155'	145'	135'
30	300'	250'	230'	215'
35	460'	375'	345'	320'

NOTES:

1. For Table 2.08A - off right-of-way runoff shall be controlled to prevent concentrated cross flow in super-elevated sections.
2. Super elevations may only be used with the written approval of the City Engineer. Where super elevation is used, street curves should be designed per AASHTO guidelines except that the maximum super elevation rate of 0.04 shall be used. If terrain dictates sharp curvature, a maximum super elevation of 0.06 is justified if the curve is long enough to provide an adequate super elevation transition.
3. On local streets, requests for design speeds less than 25 miles per hour shall be based on topography, right of way, or geographic conditions which impose an economic hardship on the applicant. Requests must show that a reduction in center line radius will not compromise safety. There will be posting requirements associated with designs below 25 miles per hour.
4. Off-set crown cross-sections are not acceptable as super elevation sections.
5. Super elevation transitions shall be designed to not allow concentrations of storm water to flow over the travel lanes.

Low speed curves may be used on residential local streets. Minimum centerline and curb radius for low speed curves shall be as follows:

	<u>Up to 75°</u>	<u>75° & Over</u>
A. Minimum Centerline Radius (2-lane)	100'	55'
B. Minimum Curb Radius	80'	35'

2.09 Vertical Alignment

Street alignments shall meet the following requirements:

- Minimum tangent street gradients shall be one-half (0.5) percent along the crown and curb.
- Maximum street gradients shall be fifteen (15) percent for residential streets, and ten (10) percent for all other streets. Grades in excess of fifteen (15) percent must be approved in writing by the City Engineer on an individual basis.
- Local streets intersecting with a residential collector or greater functional classification street or streets intended to be posted with a stop sign shall provide a landing averaging five (5) percent or less. Landings are that portion of the street within twenty (20) feet of the projected curb line of the intersecting street at full improvement.
- Grade changes of more than one (1) percent shall be accomplished with vertical curves.

- At street intersections, the crown of the major (higher classification) street shall continue through the intersection. The roadway section of the minor street will flatten to match the longitudinal grade of the major street at the projected curb line.
- Street grades, intersections, and super elevation transitions shall be designed to not allow concentrations of storm water to flow across the travel lanes.
- Off-set crowns shall be allowed only with the specific prior approval of the City Engineer.
- Slope easements shall be dedicated or obtained for the purposes of grading outside of the right-of-way.
- Streets intersected by streets not constructed to full urban standards shall be designed to match both present and future (as far as practicable) vertical alignments of the intersecting street. The requirements of this manual shall be met for both present and future conditions.

When new streets are built adjacent to or crossing drainage ways, the following standards shall govern the vertical alignment:

Functional Classification	Vertical Standard
Arterial Streets	Travel lanes at or above the 50 year flood elevation but not lower than 6 inches below the 100 year flood elevation
All other streets	Travel lanes at or above the 25 year flood elevation but not lower than 6 inches below the 50 year flood elevation

If alternate access is available for properties served by a particular local street, a design could be considered for approval by the City Engineer that would set the travel lanes at or above the 10 year flood elevation but not lower than 6 inches below the 25 year flood event.

Crest and sag vertical curves shall conform to the values found in Tables 2.09A and 2.09B. At controlled intersections, the K-value for crest vertical curves may be reduced, if approved by the City Engineer.

Table 2.09A
Design Controls for Crest Vertical Curves
Based on Stopping Sight Distance

Design Speed	Minimum k
25	20
30	30
35	40
40	60
45	80
50	110
55	150

Table 2.09B
Design Controls for Sag Vertical Curves
Based on Stopping Sight Distance

Design Speed	Minimum k
25	30
30	40
35	50
40	60
45	70
50	90
55	100

AASHTO provides the designer of sag vertical curves the option of using shorter curves with the installation of street lighting. These "comfort" designs can also be slightly modified by providing a one (1) percent grade break at each end of the curve. Table 2.09C compares sag curve lengths using these criteria.

Table 2.09C – Design Controls for Lighted Sag Vertical Curves
25 Miles per Hour

Algebraic Difference in Grades	Standard (k)	Comfort (k)	Comfort with Grade Breaks (k)
5.00%	30	13.4	8
7.50%	30	13.4	9.9
12.50%	30	13.4	11.3
17.50%	30	13.4	11.9

At the intersection of a local street with another local street or a minor collector street, a minimum design speed of 15 MPH is allowed on the intersecting street. Minimum k factors for lighted sag curves are shown in Table 2.09D.

Table 2.09D – Design Controls for Lighted Sag Vertical Curves
 15 Miles per Hour

Algebraic Difference in Grades	Comfort (k)	Comfort with Grade Breaks (k)
5.00%	4.8	3
7.50%	4.8	3.6
12.50%	4.8	4.1
17.50%	4.9	4.3

2.10 Transitions

- A. Street width transitions from a narrower width to a wider width shall be designed with a 3 to 1 taper. Delineators, as approved by the City Engineer, shall be installed to define the configuration.
- B. For street width transitions from a wider width to a narrower width, the length of transition taper shall be determined as follows:
 - $L = S \times W$ (for $S = 45$ MPH or more)
 - $L = \frac{W \times S^2}{60}$ (for $S =$ less than 45)

Where L = minimum length of taper (feet)
 S = Design speed (MPH)
 W = EP to EP offset width
- C. Delineators, as approved by the City Engineer, may be installed to define the configuration. Maximum spacing of delineators shall be the numerical value of the design speed, in feet (i.e. 35- foot spacing for 35 MPH).
- D. In situations where a tapered transition cannot be provided, a barricade shall be installed at the end of the wider section of the street and a taper shall be appointed and delineated as approved by the City Engineer. The barricade shall conform to the Standard Drawing. If the wider section does not provide an additional travel lane, only a barricade is required without the transition.

2.11 Street Frontage Improvements

- A. All residential subdivisions, commercial developments and short plats shall install street frontage improvements at the time of construction as detailed in their subdivision or short plat approval, as detailed in their approved building plans, or as directed by the City Engineer. Such improvements as determined by the City Engineer shall commence from the centerline of the right-of-way and is to include: sawcut and replacement of existing pavement and road section to the centerline of the traveled way or the centerline of right-of-way; curb and gutter; sidewalk; street storm drainage; street lighting system; traffic signal modification, relocation or

installation; utility relocation; landscaping and irrigation and street widening all per these Standards. Plans shall be prepared and signed by a licensed civil engineer registered in the State of Washington. Any modification to the requirement for a half-street improvements must be approved by the City Engineer before preliminary land use approval with the approved modification to be set forth in a "Condition of Approval" for the specific project. If the existing pavement in the remaining half street opposite the project frontage is found to be in substandard condition as determined by a geotechnical engineer for the traffic generated by the project, and/or if any additional longitudinal utilities are to be installed with the frontage improvements within the existing paved width opposite the project frontage, an additional overlay may also be required over the that half of the street for the extent of the frontage improvements as determined by the City Engineer.

- B. Plan Preparation shall be as specified in Chapter 1 of these Standards.
- C. Street Frontage design shall incorporate all applicable sections of these Standards and other standard reference materials. The designer shall utilize good engineering practice in any situation not specified in these Standards.

2.12 Street Ends

- A. Turnarounds shall be provided at all public street ends and ends of private streets longer than one hundred fifty (150) feet.
- B. Cul-de-sacs shall be provided for all streets longer than 150 feet. Hammerheads may be used in lieu of a cul-de-sac as approved by the Fire District and City Engineer provided that the street serves eight (8) or less lots and the street is less than one hundred and fifty (150) feet in length.
- C. Temporary Dead Ends. Where a street is temporarily dead ended, turn around provisions must be provided where the road serves more than four lots. The turn around may be a hammerhead as approved by the Fire District and the City Engineer if the dead end is less than one hundred and fifty (150) feet in length. If over five hundred (500) feet long, a cul-de-sac with a minimum paved radius of forty-five (45) feet is required for residential streets with mountable curbs, and forty-eight (48) feet for industrial streets. All temporary turnarounds shall be asphalt; gravel surfaces will not be acceptable.

In the event a temporary turnaround is installed on a street that will be extended in the future, the party responsible for extending the road shall also be responsible for removing the temporary turnaround and installing all necessary curbing, sidewalk, landscaping, etc. within the removal area to meet current City standards.

- D. Design Requirements. The following specifies the minimum requirements for cul-de-sacs, eyebrows, and turnaround areas. Other turnaround geometrics may be used when conditions warrant and City Engineer approves the design and application of its use.
 - 1. Cul-de-sacs shall have a minimum outside curb radius of forty-five (45) feet for residential streets and forty-eight (48) feet for industrial streets.

2. Cul-de-sacs, eyebrows, and turnaround areas shall be allowed only on local and commercial/industrial streets.
3. Cul-de-sacs shall be not be more than five-hundred (500) feet in length unless serving a topographically isolated area (such as a narrow ridge) as determined by the Community Development Director and City Engineer. The length of a cul-de-sac shall be measured along the center line of the roadway from the near side right-of-way of the nearest through traffic intersecting street to the farthest point of the cul-de-sac right-of-way.
4. The minimum curb radius for transitions into cul-de-sac bulbs shall be twenty-five (25) feet.
5. The right-of-way radius for the cul-de-sac shall be sufficient to maintain the same right-of-way to curb spacing as in the adjacent portion of the road (i.e. a local residential street requires forty five (45) foot curb radius with a fifty five(55) foot right-of-way radius)
6. It is the City of Ridgefield's policy to discourage the use of hammerheads and to only permit them under unusual circumstances as applied with small infill developments of a maximum of eight (8) lots. Hammerheads may be used in lieu of a cul-de-sac provided that the street serves Eight (8) or less lots and the street is less than two hundred (200) feet in length. Hammerhead geometry shall be approved by the Fire District and the City Engineer.
7. An eyebrow corner may be used on a local street where expected ADT will not exceed 500 vehicles per day or as otherwise approved by the City Engineer. Minimum curb radius on the outside of an eyebrow corner is 36 feet; minimum right-of-way radius is 45 feet. Eyebrow geometry shall be evaluated on the basis of turning requirements for Fire Department vehicles.
8. The turnaround shall be posted and painted "Fire Lane - No Parking".

2.13 Medians

- A. A median shall be in addition to, not part of, the specified roadway width unless shown on the standard street cross-sections. Medians shall be designed so as not to limit turning radius or sight distance at intersections. Landscaping and irrigation shall be installed when directed by the City Engineer.
- B. Where raised medians are allowed, the following criteria must be met:
 1. Edges shall be vertical curb in urban areas, and either vertical curb or thickened edge in suburban areas.
 2. Landscaping and irrigation are required. Plans shall be prepared by a qualified Landscape Architect.
 3. Raised medians shall be designed so as not to limit turning radius or sight distance at intersections.
 - The raised median shall be set back at least 1 foot from the median lane on both sides, unless otherwise approved by the City Engineer

- Street lighting shall be sufficient to provide illumination of the raised median.
- Objects, such as trees, shrubs, signs, and light poles shall not physically or visually interfere with vehicle or pedestrian traffic in the travel way.
- The style and design of the raised median shall be site specific. The raised median shall be safe for the design speed, and shall be subject to City approval.

2.14 Intersections and Curb Returns

- A. Traffic control will be as specified in the Manual of Uniform Traffic Control Devices (M.U.T.C.D.) or as modified by the City Engineer as a result of appropriate traffic engineering studies.
- B. Traffic signal modification, relocation or installation is required when roadway or driveway geometrics interfere with existing signal facilities, or would result in an unsignalized approach or intersection that meets signal warrants.
- C. Angle between intersections. The interior angle at intersecting streets shall be kept as near to 90 degrees as possible and in no case shall it be less than 75 degrees. A tangent section shall be carried a minimum of 25 feet each side of intersecting right-of-way lines.
- D. Maximum street spacing - 500 feet.
- E. Minimum centerline offset of adjacent streets.
 1. Residential - 160 feet
 2. Residential or arterials intersecting arterials - 300 feet
- F. Sloping approaches. On sloping approaches, including commercial driveways, garage entrances, and private street openings, landings are not to exceed two (2) feet difference in elevation for a distance of thirty (30) feet approaching an arterial or twenty (20) feet approaching a local collector or industrial or commercial street, measured from the back of sidewalk or the back of curb if no sidewalk exists.
- G. Curb returns. Curb radii at intersections shall be in accordance with Table 2.14A for the various functional classifications. The right-of-way radii at intersections shall be sufficient to include the entire sidewalk and ramp within the public right-of-way and shall have a minimum radii of 20-feet.

**Table 2.14A - Turning Radii (Feet)
 Edge of Pavement/Curb -Minimums**

Street Classification	Major/Minor Arterial Street	Residential Collector Street	Commercial Industrial Street	Residential Access/Local Street
Major/Minor Arterial Street	55	30	40	25
Residential Collector Street	30	25	30	20
Commercial Industrial Street	40	30	40	25
Local Street	25	25	20	20

* If bike lane or on-street parking exists, above radii may be reduced by five (5) feet.

* The radii of the major street will be used for all intersection curb returns.

2.15 Sight Obstruction Requirements

- A. Sight distance should be maintained at all driveways, building or commercial garage entrances where structures, wing walls, etc. are located adjacent to or in close proximity to a pedestrian walkway.
- B. Sight lines to traffic control devices (signs, signals, etc.) should not be obscured by landscaping, street furniture, marquees, awnings or other obstructions. Refer to the Manual of Uniform Traffic Control Devices (M.U.T.C.D.) for required sightlines.
- C. Sight Distance. It is the policy of the City to have the developer's engineer evaluate safe intersection sight distance using the principles and methods recommended by AASHTO. Table 2.15A presents minimum intersection and driveway sight distances.

Table 2.15A - Corner Sight Distance

Design Speed (MPH)	Minimum Corner Sight Distance (Feet)
20	210
30	310
40	415
50	515
60	650

Intersection sight distance should always be measured from a driver's eye 3.5 feet high and 15 feet from the near edge of the nearest lane to an object height of 3.5 feet. Stopping sight distances must also be checked on the actual vertical and horizontal values of the proposed improvement. There shall be nothing to block observation of objects between the driver's eye height of 3.5 feet and an object height of 2.0 feet above grade in both directions. The only exceptions should be for luminaire or utility poles, conforming traffic control devices, and fire hydrants. Cumulative effects must be considered, and all efforts taken to minimize sight obstructions.

Modifications or exceptions to these standards shall be approved by the City Engineer.

2.16 Curb and Gutter - Types and Application

- A. Vertical curb and gutter shall be utilized on all streets (residential, commercial or arterial) and on all islands and medians except when emergency vehicle access across the median is required.

Rolled Curb may be used at the end of cul-de-sacs where approved by the City Engineer.

- B. The following specifies the requirements for curbs and cross-slope grading for streets:
1. All streets shall include curbs on both sides, except in the situations of interim width improvements. Interim designs, where approved in writing by the City Engineer, shall have shoulders and ditches.
 2. Interim width streets shall have 2-foot side shoulders adjacent to the street at a 2 percent cross-slope and roadside ditches each side of the shoulders with a maximum side-slope of 2 horizontal to 1 vertical. The 2-foot shoulder area may consist of a section of pavement and/or a section of crushed rock. The pavement section shall be a minimum of 2 feet wide and a maximum of 6 feet wide.
- C. Grading outside the improved areas shall be as follows, unless approved in writing by the City Engineer:
1. Arterials shall have a maximum 2 percent upward grading to the right-of-way line, and no steeper than 3 to 1 up, or 3 to 1 down, outside the right-of-way.
 2. Local Street and Commercial/Industrial functional classifications shall have a maximum 2 percent upward grading to the right-of-way line, a 5 to 1 upward or downward grading within the public utility easement, and no steeper than 3 to 1 up, or 3 to 1 down outside the public utility easement.
 3. Retaining walls shall be used if slopes are greater than the 3 to 1 requirement in the paragraphs above or where slope stability is a problem.
 4. If slopes are to be maintained (mowed) by the City, a maximum of 4 to 1 slope will be required.

2.17 Survey Monuments

As a minimum standard for monumenting city right of ways, survey monuments shall be located at each street intersection, intersection points of the extension of the project perimeter boundary lines and the centerline of frontage streets; right of way PC, PT, bends and intersections with all property lines including the perimeter boundary lines of all subdivisions and short plats. Additional monumentation may be required by the City Engineer.

2.18 Concrete Sidewalks

- A. Where Required. Concrete sidewalks shall be provided as follows:
 - 1. Both sides of all arterial streets.
 - 2. Both sides of all other streets (through street or dead-end).
- B. Exceptions. Sidewalks may be omitted under the following conditions if approved by the Community Development Director and the City Engineer:
 - 1. Where subdivision design provides an acceptable surfaced and maintained internal walkway system as approved by the City Engineer, a sidewalk may not be required adjacent to the street.
 - 2. At the discretion of the City Engineer, private roads may require sidewalks on at least one side of the private road, as needed for connection to a pedestrian path or multiuse trail.
 - 3. Alleys do not require sidewalks.
 - 4. Where roadways abut sensitive lands, the sidewalk may be omitted from one side of the street, provided that an acceptable alternative pedestrian route is provided.
- C. Width
 - 1. Residential Streets: five (5) feet.
 - 2. Local Commercial/Industrial Streets: six (6) feet.
 - 3. Arterial Streets: six (6) feet (Except downtown arterial which requires ten (10) feet sidewalks with tree wells.
 - 4. Designated Bikeways: Ten (10) feet when there is insufficient roadway width for bicycle lanes. Bicycle lanes shall be five (5) feet in width.
 - 5. Width of sidewalk does not include curb.
 - 6. Meandering sidewalks shall maintain the full design width around obstructions that cannot be relocated. Additional Right-of-Way (or easement) may be required to either relocate the obstruction or meander the sidewalk.
 - 7. Sidewalk widening behind a mailbox shall be five (5) feet long with a ten to one (10:1) taper to the standard sidewalk section.
- D. Material. All sidewalks shall be four (4) inch thick Class B concrete over 2 inches of crushed rock. At driveways the concrete shall be six (6) inches thick.
- E. Landscape/Separation. Where planter strips are required, the back of sidewalk should be placed at the right-of-way line, unless approved by the City Engineer. Meandering sidewalks may be allowed where they provide an attractive planned alternative to straight sidewalks. A minimum three (3) foot separation between the back of the curb and sidewalk is required for landscaping and appurtenance locating purposes unless no practicable alternative exists and when approved in writing by the Engineer. Sidewalks shall meander no more than six (6) feet from the curb at all pedestrian crossings and at driveways.

- F. Handicap Ramps. In accordance with State law, wheelchair ramps meeting current Americans with Disabilities Act (ADA) requirements shall be provided at all pedestrian crossings with curb sections.
- G. Curb Ramps. The edge of the sidewalk shall merge into curb ramps. One ramp is used on each curb return on residential streets and unsignalized intersections. At signalized intersections, a curb ramp shall be aligned with each crosswalk.
- H. All handicap and curb ramps with tangents greater than 5% shall be specifically designed by the developer's engineer. Design shall include an individual detail with elevations shown at all angle points and grade breaks within the ramp so as to indicate to the contractor how the ramp is to be installed to ADA requirements.

2.19 Asphalt Sidewalks

- A. Asphalt sidewalks may be allowed in lieu of concrete sidewalks where the sidewalk as determined by the City Engineer is deemed to be of a temporary nature (such as during construction activities) or due to future construction considerations.

2.20 Trails

A. Multi-Use Trails

1. Multi-use trails shall be a minimum of eight (8) feet wide.
2. Materials shall be per the requirements of Section 2.32.
3. Multi-use trails shall be a minimum of four (4) feet from the edge of the vehicular travel way unless no practicable alternative exists and when approved by the Engineer.
4. Maximum grade is fifteen percent (15%). Minimum curve radius is ten (10) feet.
5. Access easement termination (Type II) shall be installed as directed by the City Engineer.
6. Multi-use trails may be used as a substitute for concrete sidewalks or bike lanes in planned unit developments where the City Engineer deems that non-motorized transportation goals of the City are being met.

B. Off-Road Trails

1. All City Trail Systems are to meet the multi-use standards above as reasonably possible. For Trail Systems that can not meet the multi-use standards above, as determined by the City Engineer, the minimum standards for the design and construction shall generally follow as a practical guide for trail work the 2007 Edition of the "Trail Construction and Maintenance Notebook" and the 2007 Edition of the "Wetland Trail Design and Construction", Forest Service Publication List Document Numbers 0723-2806-MTDC and 0123-2833-MTDC respectively. These practical guides can be located on the Federal Highway Administration (FHWA) web site at <http://www.fhwa.dot.gov/environment/fspubs/>.

2.21 Bikeways/Bike lanes

- A. Bikeway construction is required in conjunction with commercial development, plat or short plat approval, when the need for such a bikeway is established by the Community Development Director.
- B. Separated bikeways (bicycles only) shall be a minimum of five (5) feet wide for one way and ten (10) feet wide for two (2) way flow. Separated bikeways combined with pedestrian facilities shall be a minimum of ten (10) feet wide.
- C. Where joint vehicular and bicycle facilities (Bike lanes) are constructed, the curb lane shall be fourteen (14) feet wide and use eighteen (18) inch wide Type A curb and gutter.
- D. Surfacing requirements for separated bikeways shall be as specified in Section 2.32.
- E. Maximum grade for separated bikeways shall be ten percent (10%). Minimum curve radius is one hundred (100) feet. Curves should be minimized.
- F. Bump outs. A "bump out" at street intersections per Standard Drawings shall be installed on all routes with bike lanes using the following criteria:
 1. Two-lane roadway - not applicable.
 2. Three-lane roadway - "bump out" at all signalized intersections only.
 3. Four- to five-lane roadway - "bump out" at all signalized intersections and at major side street intersections where the right turn volume onto the minor street exceeds 600 ADT.

2.22 Driveways

- A. General Requirements.
 1. Standard residential or commercial driveways shall be required for all developments.
 2. In new residential subdivisions or residential short subdivisions, panhandle and flag lot driveways shall be less than one hundred and fifty (150) feet and have a minimum paved access driveway of twelve (12) feet in width and shall provide access to no more than two (2) lots. The private or public road standards shall be used for access to more than two (2) lots.
 3. Only one driveway access per residential lot shall be allowed unless approved by the City Engineer.
 4. A private intersection opening shall be used in lieu of a conventional driveway in commercial areas where the following criteria or as determined by the City Engineer are met:
 - Projected driveway usage is greater than two-thousand (2,000) vehicles per day.
 - In any case where traffic signalization is approved and provided.

- A minimum one hundred (100) foot storage area is provided between the street and any turning or parking maneuvers within the development.
- The opening is at least one hundred and fifty (150) feet from any other intersection opening.
- The opening is at least one hundred and fifty (150) feet away from any other driveway on the property frontage under control of the applicant.

B. Conditions of Approval.

1. Driveways directly giving access onto arterials may be denied if alternate access is available. Driveways giving access onto other roadways may be denied, if in the opinion of the City Engineer, they create a potentially unsafe or hazardous condition.
2. All abandoned driveway areas on the street frontage to be improved shall be removed and new curb, gutter, and sidewalk shall be installed.
3. No commercial driveway shall be approved where backing onto the sidewalk or street will occur.
4. Left turns from and to a driveway may be restricted as a development condition or in the future if such maneuvers are found by the City Engineer to be unduly hazardous.
5. Driveways shall be aligned wherever possible with existing driveways on the opposite side of the street.
6. If driveways cannot be aligned directly across from a driveway on the opposite side of the street, they shall be offset a minimum of one hundred (100) feet from driveways on the opposite side of the street whenever possible.
7. All driveways shall be angled ninety-degrees (90°) to the street, unless designated as right turn only with the approval of the City Engineer.
8. Driveways approved by the City Engineer providing for access onto collectors shall be a minimum of 100 feet from any intersection, and a minimum of 150 feet for access onto arterials.

C. Design Criteria.

1. Width.

The maximum two (2)-way driveway width shall be twenty (20) feet for residential uses and thirty (30) feet for commercial uses. A wider commercial driveway width may be approved by the Engineer where a substantial percentage of oversized vehicle traffic exists and where it can be justified via modeling or some other approved means. In this case the driveway should be sized to accommodate the largest vehicles, but shall be no wider than fifty (50) feet. Where intersection openings are approved, the width shall be as determined by the City Engineer.

Maximum one way driveway width shall be ten (10) feet for residential and twenty-two (22) feet for commercial driveways. Parking lot circulation needs

shall be met on site. The public right-of-way shall not be utilized as part of a one way parking lot flow.

Driveways on local access streets serving detached single-family homes may be up to thirty (30) feet in width, subject to approval by the City Engineer. There shall be adequate top of curb space provided between detached single-family driveway aprons at the property line for location of water meters and street lighting.

2. Elevation. For new development, driveways on local access streets serving single family homes adjacent to detached sidewalk (i.e. standard detail sheets T-2.8 to T-2.10) shall match the same elevation as the front of the walk adjacent to the driveway approach. Any variation to this requirement is to follow city standards as approved by the City Engineer.
3. Clearance from structures. No object (including fire hydrants, light or power poles, street trees) shall be placed or allowed to remain within fifteen (15) feet of the driveway edge.

Where the building facade or other design element is less than ten (10) feet behind the sidewalk front setback both pedestrian and vehicular sight distance shall be maintained. Vehicular sight distance shall be per Section 2.15.

4. Sight Distance. Pedestrian sight distance shall be as follows: The driver of an exiting vehicle shall be able to view a one (1) foot high object fifteen (15) feet away from either edge of the driveway throat when the driver's eye is fourteen (14) feet behind the back of the sidewalk.
5. Maximum driveway grade shall be fifteen percent (15%).
6. On sloping approaches, a landing as described in Section 2.09, shall be provided.
7. Approach grades and configuration shall accommodate future street widening to prevent major driveway reconstruction.

2.23 Bridges

- A. Design Principles. All bridges, whether on public or private roadways, shall meet the minimum requirements set forth in the latest addition of "Standard Specifications for Highway Bridges", adopted by AASHTO. All new bridges shall be designed to carry an AASHTO HS-20-44 live load or greater.
- B. Geometrics. In the general case, the bridge shall comprise the full width and configuration of the road being served (traveled way plus curb, sidewalk, walkway, bike lane, and/or shoulder on one or both sides). Requirements of utilities shall be considered. Traffic and pedestrian railings or combination traffic-pedestrian railings shall meet AASHTO specifications. Overhead vertical clearances on the traveled street or under overpasses shall be sixteen and one-half (16.5) feet minimum.

2.24 Landscaping in the Right-Of-Way, Easements and Access Tracts

- A. Plantings established in the right-of-way shall be maintained by the abutting property owner on local and access streets. Plantings established in the right-of-way along collector and arterial streets shall be maintained by the Home Owner's Association / Business Association.
- B. Any existing planting areas within the right-of-way that are disturbed by construction activity shall be restored to their original condition.
- C. Any plantings or other improvements placed within the right-of-way (by abutting property owners) are subject to removal when the right-of-way is needed for public use. The property owner is responsible for removing any landscaping or other improvements upon official notice. The property owners shall be responsible for survival of the relocated plantings.
- D. Measures shall be taken by the developer to provide groundcover in areas within the right-of-way which have been stripped of natural vegetation or have a potential for erosion. Native plants shall be used whenever possible.
- E. Plantings within the right-of-way shall comply with the following provisions:
 - 1. All landscaping shall comply with the sight distance provisions of these standards.
 - 2. Where existing landscaping maintained by the City exists every effort shall be taken to protect and preserve the existing vegetation during construction. Plants shall be relocated or removed only upon approval of the Public Works Department. Damaged landscape areas shall be restored prior to issuing a final occupancy permit.
 - 3. In areas where an existing landscaping concept or pattern has been established or approved, all new landscaping shall conform to the intent of the concept. Plantings shall be of a similar variety, size, and spacing to those already established and/or approved for the area.
 - 4. All trees planted in areas with adjacent pedestrian usage shall maintain a seven (7) foot clearance to the lowest branches.
 - 5. Approval from the Public Works Department must be received before trees are planted in or adjacent to sidewalk sections.
 - 6. Landscaping in public right of way with low maintenance, drought tolerant ground cover is encouraged. Native plant lists and list of nuisance and prohibited plants are included in RMC Section 18.830.

2.25 Mailboxes

- A. Mailboxes should be clustered together when practical and when reasonably convenient to the houses served.
- B. When mailboxes are located in the sidewalk, individually or in clusters, sidewalk shall be widened to provide the full design width around the mail boxes.

- C. In the case of new road construction, or reconstruction requiring mailboxes to be moved back or rearranged, the designer and builder shall coordinate with the local postmaster of the U.S. Postal Service. Mailbox locations approved by the Post Office shall be shown on approved road construction plans.

2.26 Street Illumination

A. Plats and Short Plats.

Street lighting is required for all public streets. The street lighting design shall be reviewed and approved by the City Engineer prior to final plat approval. The cost of all street lighting shall be paid for by the developer.

The City will accept maintenance and power cost responsibility for the public street light system only when the public improvements have been fully accepted by the City. Until the public improvements have been fully accepted by the City, the developer is responsible for the maintenance and energy charges for the street lighting system.

Street lighting is not required on private streets within a plat. However, a street lighting system is encouraged. The City does not install or maintain private street lighting systems. On private streets, all street light maintenance and power cost shall be paid by the developer, homeowner, or homeowners association.

- B. Existing Residential Areas. If a resident or group of residents desires the installation of a new street light they must apply to the Public Works Director.

- C. Commercial. Street lighting is required on all public street frontages. The developer is responsible for design, installation or relocation of new or existing lighting. Commercial development shall replace existing lighting systems on power poles with a new lighting system serviced by underground power.

D. General Considerations.

All public street light designs shall be prepared by a licensed engineer experienced in lighting design. The design plans and calculations should indicate luminaire type, luminaire spacing, illumination levels, uniformity ratio, line losses and the electrical and physical layout of the system, including its connection to the existing system and foundation design.

Street lights shall direct light downward. Lights shall be provided with a cap or shield to prevent stray light from going upward.

All public street light systems shall be accessible for public maintenance by a wheeled vehicle weighing twenty-thousand pounds (20,000 lbs.).

All street light installations including wiring, conduit, and power connections shall be located underground. Exception: existing residential areas with existing above ground utilities may have street lighting installed on the existing power poles as approved by the Public Works Director as noted above.

As-built drawings on 22-inch x 34-inch or 24-inch x 36-inch mylar are required for all new or relocated underground street lighting systems prior to receiving a final occupancy permit.

All street lights shall be on one hundred twenty (120v) volt single phase systems. The exact location of the power source should be indicated together with the remaining capacity of that circuit. System continuity and extension should be considered.

Contractor cabinets equipped with electrical meters, time clocks, circuit breakers and other required components are required on commercial installations of five (5) or more street lights.

Particular attention shall be given to locating luminaires near intersections, at all street ends and at pedestrian and/or equestrian crossings.

- E. Illumination. Street lighting system designs are to be prepared by a licensed engineer experienced with lighting design. Calculations should include luminaire spacing, illumination level, uniformity ratio, line losses, power source and other necessary details for the electrical and physical installation of the street lighting system. The lighting engineer shall use the standard specifications of the Washington State Department of Transportation for SR-501 (Pioneer), and for all other City streets shall use the City of Vancouver city street lighting requirement.

Illumination Levels

Street Classification	Horizontal Foot Candles	Uniformity Ratio (average to minimum)
Principal Arterials	1.2 FC	3:1
Minor and Collector Arterials	0.8 FC	3:1
Local Commercial/Industrial	0.8 FC	3:1
Local Residential Collectors	0.4 FC	3:1
Local Residential Streets	0.3 FC	4:1

- F. For new subdivisions and short plats all new street lights shall be Decorative Street Lights with single luminaire with fiberglass pole (i.e. Acorn or Shepard's Hook). The luminaire shall be a 100 watt sodium vapor, decorative post top (single) street light, type 5, with internal house side shield on a 14.5' direct burial decorative fiberglass pole, at a maximum 150-foot spacing. Street light location to be 2-feet behind curb or as shown in lighting plan.
- G. Street lights for City Collectors and arterials shall be per City standard plan T-2.11 and T-2.12. The luminaire is to be a GE M-400A POWR/DOOR® WITH CUT OFF OPTICS, 200 watt/120 volt, HPS, flat internal reflector lens, black powder coat finish, mounted at 34-feet with an 8-foot arm.
- H. City pathway lights are to be approved by the City Public Works Director and shall be 50 watt sodium vapor pathway area pole light on 16-foot direct burial, round tapered, black, fiberglass pole.

2.27 Traffic Control and Signing

- A. Traffic Control Devices. The City Engineer shall review and approve all traffic control devices.
- B. Signing. In new plats the developer shall install all traffic control signs which shall include but not be limited to street name, parking, stop, dead end, and pedestrian signing. The developer will be responsible for supplying and installing the required signs.
- C. Pavement Marking. In new plats or commercial developments pavement markings, including buttons, paint, thermoplastics and delineators will be required for roadway safety. Such markings shall be provided and installed by the developer. All markings shall be approved by the City Engineer prior to installation.
- D. Temporary Traffic Control. It is the responsibility of the developer to provide adequate temporary traffic control to ensure traffic safety during construction activities.
- E. Traffic Signal Modification. Traffic signal modification designs shall be prepared by a licensed engineer experienced in traffic signal design.
- F. Design Requirements
 - 1. Traffic Control Devices. All traffic control devices shall conform to the Manual on Uniform Traffic Control Devices (M.U.T.C.D.) as adopted by the Washington State Department of Transportation (WSDOT).
 - 2. Signing. See WSDOT Standard Drawings for typical installations and details. Sign posts shall be constructed of 2"x 2" square aluminum post per the WSDOT Standard Plans.
 - 3. Pavement Marking. All markings shall conform to the current Manual on Uniform Traffic Control Devices (M.U.T.C.D.) as adopted by the Washington State Department of Transportation (WSDOT).
 - 4. Temporary Traffic Control. All traffic control devices shall conform to the Manual on Uniform Traffic Control Devices (M.U.T.C.D.) as adopted by the Washington State Department of Transportation (WSDOT) or as modified by the City Engineer.
 - 5. Speed Humps. Speed humps are approximately three (3) inches in height with a length of at least twelve (12) feet at base.
 - 6. Traffic Signal Modification. The developer's engineer shall use the standard specifications developed by the City Engineer in conjunction with the current edition of the Washington State Department of Transportation's (WSDOT) Standard Plans and Specifications for Road, Bridge, and Municipal Construction. Traffic Signal plans shall be submitted on 22" x 34" mylar.

2.28 Clear Zone and Appurtenances

An appurtenance shall be considered to be any fixed object located adjacent to the roadway and deemed to be a possible safety hazard.

- A. All non-breakaway appurtenances shall be located a minimum of three (3) feet behind the face of the curb to the face of the object. Where no curb exists the distance from the edge of the travel way to the face of the object shall be at least six (6) feet.
- B. All breakaway objects shall be located a minimum of two (2) feet behind the face of curb to the face of the object. All objects having properties up to that of a 4" x 4" wooden post shall be considered breakaway.
- C. Appurtenances shall be located outside of the sidewalk area except when the sidewalk is widened around the appurtenance to the satisfaction of the City Engineer.

2.29 Franchise Utilities

- A. Non-City owned franchise utilities are required to relocate existing facilities at their own expense when a conflict results between their facilities and public street improvements. For development related work, the proposed improvements must be required by the non-City owned utility in order for the relocation work to be the financial responsibility of the utility, otherwise all costs shall be the responsibility of the developer.
- B. All non-City owned utility distribution or collection systems, franchise or otherwise, including power, telephone, and television cable in new plats or short plats shall be underground.
- C. As a minimum on all new single family plats and short plats, a minimum five (5) foot wide common or individual non-exclusive utility easement shall be provided connecting any lots without public street frontage to a public street. Easements for existing or future utility lines which do not lie along rear or side lot lines shall be of a width specified by the serving utility.

2.30 Safety Railing

- A. Where a sidewalk or other non-motorized transportation facility is to be constructed above a slope or adjacent to a rockwall or retaining wall where the lowest finished elevation of the slope, rockwall or retaining wall is to be thirty (30) inches or more below the finished elevation of the sidewalk or other facility, a safety railing shall be required when:
 - 1. The plane of a wall face is less than four (4) feet in horizontal distance from the near side face of the sidewalk or other facility.
 - 2. The plane of the wall face is greater than four (4) feet horizontal distance to the near side face of the sidewalk or other facility but the slope down to the wall top exceeds three to one (3H:1V).
 - 3. The slopes adjacent to the sidewalk or other facility average greater than two to one (2H:1V).
- B. Safety railings or other approved devices (such as walls, high curbs, landscape features or guard rails) shall be required where grading operations will produce a

parking area, service yard or other vehicle area which has a drop-off grade separation in relation to adjoining properties or streets.

- C. Safety railings shall be constructed of 2-inch galvanized steel pipe or aluminum with vertical supports ten (10) feet on center and 3 horizontal railings fourteen (14) inches on center, the lowest railing center being fourteen (14) inches above finished grade. All joints shall be welded, cold galvanized if welded after galvanizing, and the entire safety railing painted or vinyl coated to assure corrosion protection and a pleasing appearance at the City's option. Railings shall be erected and adjusted, if necessary, after initially set to assure a continuous line and grade. Warning signs stating "Danger, Please Keep Off" shall be attached to the railing spaced every 50 feet or as directed by the City Engineer.

2.31 Guard Rails

For purposes of warrants, design, and location, all guard rails along roadways shall conform to the criteria of the "Washington State Department of Transportation Design Manual" as may be amended or revised. The decision of whether to install a guardrail or not shall be based on information found in AASHTO publication, Guide for Selecting, Locating, and Designing Traffic Barriers.

2.32 Surfacing Requirements

All materials and workmanship shall be in accordance with the Standard Specifications, these Standards, and as approved by the Engineer.

- A. Minimum Structural Section. The following are the *minimum* requirements for surfacing for specific facilities as described elsewhere in these Standards.

Facility		Surfacing Requirements
1.	Roadways	
	Arterials – Industrial/Commercial	5" Hot Mix Asphalt Class 1/2-inch, PG 70-22 over 14" crushed base rock
	Residential Collector	4" Hot Mix Asphalt Class 1/2-inch, PG 64-22 over 12" crushed base rock
	Access & Local Residential Streets	3" Hot Mix Asphalt Class 1/2-inch, PG 64-22 over 10" crushed base rock
2.	Concrete Sidewalks	4" Portland Cement Concrete over 2" of crushed base rock
3.	Multi-Use Trail	2-1/2" Hot Mix Asphalt Class 1/2-inch, PG 58-22 over 4" Crushed Rock Base, unless otherwise approved
4.	Bikeway	2-1/2" Hot Mix Asphalt Class A over 4" Crushed Rock Base

All minimum surfacing requirements assume an acceptable, well drained, stable, compacted subgrade. Additional requirements may be imposed at the discretion of the City Engineer if suitable subgrade conditions are not met. A pervious material, such as Grass Crete or Ritter Ring, may be used in parking lots upon approval of the City Engineer.

- B. Alternative Sections. Streets may be constructed of any of the following:
1. Asphaltic concrete with crushed rock base or treated base.
 2. Full depth asphaltic concrete.
 3. Portland cement concrete with cushion course of crushed rock or on a base of crushed rock or treated base.

For pavement sections, other than those in Section 2.32.A, alternative sections may be approved by the City Engineer following submission of calculations by a registered engineer and per the design requirements described herein. Soil testing to obtain the strength of the soil is required for all roads and streets in order to analyze and design the structural section. Soil tests are needed on undisturbed samples of the subgrade materials that are expected to be within three (3) feet of the planned subgrade elevation. Samples are needed for each five hundred (500) feet of roadway and for each visually observed soil type. Soil tests are required from a minimum of three (3) locations.

The selected design structural strength of the soil shall be consistent with the subgrade compaction requirements. The strength and compaction moisture content, at optimum to slightly over optimum, shall be specified. The soils report shall address subgrade drainage and ground water considerations for year round conditions.

Recommendations for both summer and winter construction shall be included. The required density of treated and untreated subgrade materials shall not be less than 95 percent maximum density as determined by AASHTO T-99.

C. Aggregate Base

All aggregate shall meet WSDOT specifications for base rock.

During compaction, materials shall be maintained within 2 percent of the optimum moisture content. The contractor shall begin compaction of each layer immediately after the material is spread, and continue until a density of not less than 95 percent of the maximum density has been achieved. Maximum density will be determined by AASHTO T-180, or WSDOT Test Method 705.

D. Asphalt Pavement Design

The base course and wearing course of asphalt concrete (AC) for streets shall be WSDOT "Superpave" Hot Mix Asphalt Class 1/2-inch, PG 64-22.

The compaction shall be at least 91 percent based on a Rice theoretical maximum density, as determined in conformance with AASHTO T 209, as modified by WSDOT. In addition, for each mix used, a 50 blow Marshall (AASHTO T 245) shall be performed and all related test data shall be provided to the City Engineer. The minimum stability shall be 1,800 pounds, the flow shall be between 8.0 and 16.0 hundredths of an inch, and the voids shall be between 3.0 and 5.0 percent. The Marshall requirement may be waived by the City Engineer on a case-by-case evaluation.

Asphalt pavement shall be designed by the Asphalt Institute Method, or an approved equivalent method provided it is a nationally recognized procedure.

Design of asphalt concrete pavement structures by the Asphalt Institute Method shall conform to the guidelines of The Asphalt Institute Publication, Thickness Design - Asphalt Pavements for Highways and Streets Manual Series No. I.

1. AASHTO T-193 (CBR Method), or
 2. AASHTO T-190 (R-Value Method), or
 3. If the CBR value of the subgrade exceeds twenty (20) or the R value of the subgrade exceeds sixty (60), then CBR and R-value methods shall not be used.
- E. Portland Cement Concrete Pavement. The design of Portland cement concrete streets shall be governed by the guidelines and requirements of the Portland Cement Association (PCA) design procedures found in the following publications:
1. Concrete Streets: Typical Pavement Sections and Jointing Details
 2. Thickness Design for Concrete Highway and Street Pavements
 3. Joint Design for Concrete Highway and Street Pavements

The subgrade shall be tested to determine the Modulus of Subgrade Reaction, k, in order to design the street structure. A correlation of CBR to k may be made using Figure 2, provided in Thickness Designs for Concrete Highway and Street Pavements. In addition, the City requires that the following be incorporated into the design and construction specifications:

1. Use a minimum twenty (20) year design period.
2. Minimum thickness of Portland cement concrete shall be five (5) inches.
3. The minimum concrete specifications shall be 5,000 psi (compressive) and 650 psi (flexural) in 28 days. The minimum cement content will be 660 pounds per yard, with a maximum water / cement ratio of 0.48. Slump shall range from 3-inch to 4-1/2-inch. Entrained air shall be from 4.0 to 6.0 percent.
4. A design joint plan shall be prepared and incorporated into the street construction plans. Longitudinal and transverse joint locations shall be clearly delineated. Transverse joints shall be skewed forward two (2) feet per lane with right and left curb street stationing noted for each end. Joint spacing (in feet) should not exceed 1.5 to 1.75 times the slab thickness (in inches). For example, an 8-inch thick slab would have a maximum joint spacing of 12 to 14 feet. The maximum length to width ratio shall be 1.25 : 1.0 for any panel unless there are other constraints that the City Engineer will examine on a case by case basis.

2.33 Utilities

- A. Depth. Underground utilities shall be buried a minimum depth of thirty (36) inches as measured from finished grade to top of utility. See Chapters 3, 4 and 5 for additional requirements.

- B. **Curb Markings.** When new curbing is being placed, a stamp shall be placed to mark where each water and sanitary sewer service crosses the curb line. The method of marking the curb shall be approved by the City Engineer and noted on the approved construction plans. If an imprinting stamp is used, the impression left for a water service shall be the letter "W"; for a sanitary sewer service, it shall be the letter "S". These impressions shall be two (2) inches high, placed on the face of the curb.
- C. **Trench Restoration.** Trench restoration shall be either by a patch or overlay method as determined by the Public Works Director or the City Engineer. Unless otherwise approved, trenches cut in the travel lane parallel to the roadway will require a grind and overlay of the entire travel lane from the centerline to the edge of pavement. When a patch method is used, the trench limits shall be saw cut prior to the final patch.

All trench and pavement cuts shall be made by saw cuts. The saw cuts shall be a minimum of one (1) foot outside the trench width. If the permit requires an overlay, the contractor may use a zipper or other approved method for the cutting of the existing pavement.
- D. **Utility Locations.** Utilities shall be located horizontally within the right-of-way in accordance with City Standards.

2.34 Traffic Calming

Traffic calming measures shall be used by the developer on all Collector and Residential Access streets to reduce traffic speeds unless otherwise approved by the City Engineer. Traffic calming measures may also be required by the City Engineer and/or Community Development Director to mitigate traffic impacts or as required by Ridgefield Municipal Code. Acceptable traffic calming measures are provided in Appendix A.

CHAPTER 3
STORM DRAINAGE

CHAPTER 3 - STORM DRAINAGE

3.00 General Approval Requirements

- A. See Chapter 1 for general construction requirements, including the requirements for extension of all drainage conveyance pipes to limits of property, surety bond, utility review, and other general requirements.
- B. These requirements shall apply to all storm drainage facilities in existing and proposed public right-of-way, public drainage easements, and tracts of common ownership in the City. Storm drainage systems include, but are not limited to: inlets, pipes, ditches, creeks, rivers, wetlands, and stormwater quality and quantity facilities.

3.01 Planning Criteria

- A. The City of Ridgefield has established the requirements for the design of facilities intended to protect the public health, safety, and welfare from damage due to flooding. Beyond that level of protection, additional measures are specified in this chapter which are intended to minimize any potential flooding damage and allow for efficient operation, repair, and maintenance of the storm drainage system.
- B. In residential and commercial development, storm sewer main extensions are required to assure orderly and adequate extension of the storm sewer system. These extensions are to be in accordance with requirements of development and service availability as established by the City and the Washington State Department of Ecology.
- C. For development proposals that may contribute to areas of known flooding as determined by the City Engineer, the initial land use application submittal for development proposals, as determined by the City Engineer, may be required to include an off-site analysis report beyond what may be required by the referenced Washington State Department of Ecology Manuals. The off-site analysis is to contain an assessment of potential off-site drainage impacts associated with the development proposal; and propose appropriate mitigations to those impacts.
- D. Design and construction of drainage facilities, including but not limited to: open channels, conveyance pipe, and inlets shall be in compliance with the latest addition of the City's Ordinances, these Standards, the Standard Details and the 1992 edition of "Stormwater Management Manual for the Puget Sound Basin" (hereinafter referred to as the Puget Sound Manual) prepared by the Washington State Department of Ecology, as amended herein.
- E. Storm drainage pipes shall be extended through and to the extremes of the property being developed along the natural drainageways, to provide connection points for future development of unserved property as determined by the City Engineer.. No private storm sewer shall be located within any lot other than the lot which is the site of the building or structure served by such sewer. The exception to this may be common areas in planned unit developments, and/or City right-of-ways, or as otherwise approved by the City Engineer.

- F. Provisions must be made for gravity drainage of roofs and foundation drains for all new buildings and structures. Roof and foundation drains shall be piped directly to on-site stormwater systems, through private easements if necessary, or pipe through the curb and discharged to the gutter unless otherwise approved by the City Engineer.
- G. Provisions must be made for stormwater from private property to remain on private property or be collected and directed to a public or private stormwater system or natural drainageway. Runoff from that portion of driveways behind the back of sidewalk (outside the right-of-way) may be permitted to drain directly to the street, provided that treatment and detention facilities are sized to handle this flow.
- H. Stormwater systems on private property shall be design and constructed to the most recent addition of the Uniform Plumbing Code.
- I. Private stormwater systems that connect to a public conveyance system routed to a local public stormwater facility may be required to be designed and constructed to public standards as required by the City Engineer.
- J. Check that base map conforms to all requirements listed in the water and sewer utilities standard plan format per Chapter 1.

3.02 General Design Requirements

- A. The City of Ridgefield has adopted the 1992 Puget Sound Manual as amended herein.
- B. The City encourages the use of “Sustainable Street” concepts and also Low Impact Development (LID) concepts and techniques. Low-Impact Development (LID) techniques shall generally be designed in conformance with the 2005 Low Impact Development Technical Guidance Manual for Puget Sound, published by the Puget Sound Action Team/WSU Pierce County Extension.

3.03 Water Quantity Standards

- A. The minimum standards for the design and construction of stormwater quantity facilities in the City of Ridgefield shall be the same as the 1992 Puget Sound Manual as amended by Clark County Code Section 40.380, as included in Appendix A.
- B. The provisions of this section apply to all development or redevelopment that:
 - 1. Results in five thousand (5,000) square feet or more of new effective impervious surface within an urban area;
 - 2. Results in the addition or replacement of more than one thousand (1,000) square feet of effective impervious surface for any of the development activities, or redevelopment listed in Clark County Code Sections 40.380.040(B)(7)(a) and (B)(7)(b), building areas excluded;
 - 3. Redevelopment that results in ten thousand (10,000) square feet or more of replaced effective impervious surface is subject to the provisions of Clark County Code Section 40.380.040(B)(3).

Definitions; “effective impervious surface” shall be defined as those impervious surfaces that are connected via sheet flow or discrete conveyance to a drainage

system. Impervious surfaces on residential development sites are considered ineffective if the runoff is dispersed through at least one hundred feet of native vegetation. For small residential infill development sites of 8 lots or less, and at the discretion of the City Engineer, the existing impervious areas may be deducted from the total proposed (developed) effective impervious area for the threshold calculation of the “new effective impervious area”.

- C. If a site is proposed to be constructed in phases, the first phase shall have a stormwater facility designed to accommodate the ultimate development of the site. The stormwater facility may be constructed in phases provided a plan for phasing is submitted and approved by the City Engineer.

3.04 Design of Conveyance Facilities

- A. Design of conveyance systems shall be in accordance with Chapter III-2 of the Puget Sound Manual.
- B. Storm drain conveyance systems shall be sized to convey the 25-year storm event with zero property damage at the 100-year storm event. Where a natural drainageway is designated to remain in open-space as shown on the City's Comprehensive Plan, and that drainageway is not part of the regional conveyance facility, stormwater shall be conveyed through that drainageway by closed conduit sized for the 10-year storm event.
- C. Pipelines shall be designed as required below:
1. The minimum pipe size for stormwater main lines shall be 12-inches. The minimum size for pipes connecting inlets to mainline shall be 8-inches.
 2. The minimum slope for stormwater mainlines shall be 0.5%. Minimum slope for pipes connecting mainlines to inlets shall be 1%.
 3. Manholes shall be used to connect inlet lines to mainlines and at all locations where there is a change in direction and/or slope.
 4. All inside drops and pollution control structures must be 60 inch or larger diameter structures and must be constructed with pipes; no partitions will be allowed.
 5. All storm sewer pipe installed in the City shall be one of the following materials meeting the requirements of the Standard Specifications:
 - Smooth Walled Corrugated Polyethylene (ADS N-12 or equal)
 - PVC Sewer Pipe (ASTM D-3034)
 - Gasketed concrete pipe
 - Class 52 ductile iron
 - PVC Pressure Pipe (AWWA C-900)
 6. All trench backfill material shall be imported crushed surfacing base course per the Standard Specifications Section 9-03.9(3).
 7. Pipe anchor blocks shall be shown at 20 feet on center where pipe slope exceeds 20%.
 8. Horizontal Locations

- a. Locate storm sewer mains in public right-of-way per City Standards.
 - b. Outside of right-of-way, locate utilities in easements through paved areas wherever practical. Particular attention should be given to avoiding landscaped areas where trees may be planted.
9. Cap end of existing sewer lines to be abandoned as follows:
- a. Asbestos cement lines: use end cap coupling equal to ROMAC EC501.
 - b. Cast or ductile iron lines: use M.J. cap or plug
 - c. Clay or concrete lines: fill end of line with cement concrete minimum of 12 inches from end of line.
 - d. Plastic lines: use cap or plug fitting compatible with plastic pipe to be abandoned.

10. Depth of Bury (Cover) and Special Protection

- a. Storm sewer pipe shall be installed with a minimum depth of bury from finished grade of 3 feet unless otherwise approved by the City Engineer. In no case will the depth of bury from finished grade be less than 2 feet or greater than 20 feet. Pipe material shall be based on depth of bury from finished grade as outlined below:
 - i. 2 feet to 3.0 feet: Ductile iron pipe or AWWA C900.
 - ii. 3.0 feet to 20 feet: Any pipe listed in 3.05B.5 above.
- b. Storm sewer pipe shall be encased in steel casing when crossing under rockeries or retaining walls. The casing shall extend beyond footings or rockery face a minimum of 5 feet or the height of the wall or rockery, whichever is greater.
- c. Changes in pipe material may only occur at structures.
- d. Buried metal pipe shall be encased in 8-mil polyethylene per AWWA C-105, where required by the City.

D. Manholes

1. Maximum length of main line between manholes shall be 400 feet.
2. Where inlets connect to manhole, invert of inlet shall be equal to or above main sewer crown, but not to exceed 18 inches above the invert of the main sewer.
3. Manhole Sizing
 - a. 48-inch diameter manhole
 - Up to 4 connecting pipes, 8-inch to 12-inch in diameter.
 - b. 54-inch diameter manhole
 - 2 connecting pipes, 15-inch to 21-inch in diameter
 - 3 connecting pipes, 12-inch to 15-inch in diameter
 - 4 connecting pipes, 12-inch to 15-inch in diameter

- c. 72-inch diameter manhole
 - 2 connecting pipes, 21-inch to 24-inch in diameter
 - 3 connecting pipes, 15-inch in diameter
 - 4 connecting pipes, 15-inch in diameter
 - d. The minimum angle between the incoming and the outgoing pipe shall be 90°, unless otherwise approved by the City Engineer. Pipe shall be radial with the center of manhole.
 - e. The above configurations shall provide adequate shelves and room for maintenance and performing T.V. inspections.
 - f. For other pipe configurations, the size of the manhole will be determined on a case by case basis.
4. Minimum manhole depths (invert to top of rim) shall be as follows:

Manhole Size	Pipe Size	Min Manhole Depth	Comments
48"	6"	3.0'	Special manhole per Std. Detail
	8"	3.2'	
	10"-12"	3.5'	
54"	8"	3.7'	Special manhole per Std. Detail
	10"-12"	4.0'	
	15"-18"	4.5'	
72"	15"	8.0'	Flat top manhole, 2 Access lids (one over each major pipe entrance/exit)
	18"-24"	8.5'	
	27"	9.0'	

Notes: 72-inch manholes over 11.5 feet in depth shall include 48-inch reducing section per the standard detail.

5. Access shall be provided to every manhole and shall be appropriately sized for maintenance vehicles as determined by the City Engineer. In necessary locations as determined by the city engineer, access may be provided to every other manhole.
- D. Building setback requirements:
- 1. 5 feet minimum from covered parking.
 - 2. 10 feet minimum from buildings and retaining walls, or equal to depth of pipe, whichever is greater.
 - 3. 20 feet minimum easement shall be provided between buildings.
 - 4. When passing between any two buildings (residential or commercial, etc.) which are 25 feet apart or less: the sewer line shall be oversized two (2) nominal pipe sizes above the capacity requirements between nearest manholes beyond limits of buildings.

3.05 Clearances / Other Utilities

- A. Water services and inlet lines shall have at least 5 feet horizontal separation.
- B. Check for crossing or parallel utilities. Maintain minimum vertical and horizontal clearances. Avoid crossing at highly acute angles (smallest angle measure between utilities should be between 45 and 90 degrees).
- C. Horizontal clearances between the storm sewer and all other utilities shall be a minimum, of 5 feet.
- D. Vertical clearances between the storm sewer and all other utilities shall be a minimum of 1 foot.
- E. The developer/contractor shall send a letter and preliminary plan to existing utilities to inform them of new construction and shall request as-built information for incorporation into plans. At a minimum the following utilities shall be contacted:
 - 1. Cable television
 - 2. Natural gas
 - 3. Power
 - 4. Telephone

3.06 Connections to Existing Systems

- A. New storm sewer mains shall connect to existing storm sewer mains at existing manholes, or with new manhole on existing sewer per standard detail.
- B. Where new main is larger in diameter than existing downstream main, check that capacity of existing main is not exceeded by flow from new main.
- C. When connecting to existing manhole, check that requirements of Section 3.05C above are satisfied.
- D. If connecting to existing manhole which has access less than 24 inches in diameter and/or concentric cone (manholes over 5 feet deep), manhole shall be upgraded to include new 24-inch frame and cover and/or eccentric cone.
- E. Connections to end of existing pipe:
 - 1. If end of pipe is known to have a bell and the new pipe is same material as existing, plans can specify connection by inserting spigot of new pipe into the existing bell end.
 - 2. If existing line is plain end, or must be cut, plans shall specify use of a coupling to connect new and existing lines.
- F. Approved couplings for use on storm sewer mains include:
 - 1. Ductile iron mechanical couplings (equal to ROMAC) on ductile iron, concrete, or pipes with differing materials or diameters.
 - 2. On PVC or PE mains, PVC or PE couplings with compatible dimension ratio and gaskets to connect new and existing pipes shall be used.

3.07 Design of Stormwater Inlets

Stormwater inlets shall be designed and installed so that stormwater does not accumulate on or flow across roadways. The following general guidelines shall be used in designing stormwater inlets:

1. Inlet spacing shall be based upon the amount of water that each inlet can capture. Inlet calculations shall be included in the Stormwater Technical Information Report.
2. In lieu of providing inlet calculations, the following maximum inlet spacing may be used:

Roadway Slope (%)	Maximum Spacing (lf)
0.5 to 1	200
1 to 6	350
6 to 8	250
8 to 12	150
12 to 15	100

3. For most cases, inlets should be Type 1 catch basins with herring bone grates. For slopes greater than 4%, vaned grates should be used. At the bottom of sag vertical curbs, combination curb inlets should be used.
4. Curb inlets may be used in certain situations with approval of the City Engineer.
5. Inlets should not be located directly in front of ADA ramps. Inlets should be located so as to reduce the amount of water passing in front of ADA ramps.
6. Catch basins shall be WSDOT Type 1 or Type 2, as necessary. Type 1 catch basins shall have a minimum catch of 18-inches below the invert. Type 2 catch basins shall have a minimum catch of 24-inches below the invert.

3.08 Design of Stormwater Detention Facilities.

Stormwater detention facilities shall be designed to provide adequate access for maintenance. The following general guidelines shall be used in designing stormwater detention facilities:

1. Facilities shall be designed in accordance with the 1992 Puget Sound Manual.
2. Stormwater facilities with open water surfaces to be dedicated to the City of Ridgefield shall be fenced and provided with locked gate, unless approved by the City Engineer.
3. Facilities shall be provided with a paved access road with a maximum slope of 15%, unless approved by the City Engineer. Gravel access roads are allowed in private facilities that are to be privately owned and maintained. Gravel access roads shall not exceed 12%.
4. A turnaround shall be provided for all access roads unless approved by the City Engineer.

3.09 Maintenance and Ownership.

1. **City Ownership of Stormwater Facilities – When Required.** City ownership of stormwater facilities is required for all such facilities that are to be located within a public right-of-way or for which arrangements for private long-term maintenance which are acceptable to the City Engineer have not been made.
2. **Acceptance of Ownership by the City.**
 - a. **Provisional Acceptance.** Stormwater facilities, which are to be owned by the City, will be provisionally accepted for ownership upon the approval of the record drawings and approval of an inspection of the facilities by the City. Provisional acceptance of the facilities shall not relieve the applicant from any obligation to undertake any remedial measures to correct deficiencies in the design, construction, maintenance or operation of the facilities.
 - b. **Final Acceptance of Ownership by the City.** No sooner than twenty four (24) months following the provisional acceptance of the facilities, the applicant shall notify the City Engineer that the facilities are eligible for final acceptance of ownership by the City. Prior to their final acceptance for ownership, the facilities shall be inspected to determine that they are in satisfactory condition. The City Engineer may require the applicant to conduct tests of the facilities to reasonably demonstrate that they are operating as designed and to the City standards for quality and quantity control as a condition of final acceptance. Upon approval of the facilities by the City Engineer and all necessary ownerships and easements entitling the City to properly access and maintain the facilities have been conveyed to the City and recorded with the County Auditor, they will be finally accepted for ownership by the City.
3. **Maintenance of Stormwater Facilities.**
 - a. **City-Owned Facilities.**
 1. **Initial Maintenance and Repair.** For a period of at least two (2) years following the provisional acceptance of stormwater facilities or thereafter until the facilities are finally accepted by the City, the developer constructing the facilities shall maintain, repair, redesign, reconstruct the facilities to ensure that they operate as designed and to the City standards for quality and quantity control. This obligation shall extend to remedying any damage caused to the facilities by builders or other third parties during the initial maintenance period. The required maintenance shall be performed according to the Stormwater Facilities Maintenance Manual as adopted by Clark County (refer to Clark County Code Chapter 13.26A).
 2. During the initial maintenance period, remedial work to correct deficiencies shall be the responsibility of the developer and shall be completed prior to final acceptance. Required remedial work to correct maintenance and construction deficiencies shall be completed by the applicant prior to final acceptance.
 3. **Long-Term Maintenance.** Following their final acceptance for City ownership, the City shall maintain stormwater facilities.
 - b. **Privately Owned Facilities.**

1. Responsibility for Maintenance. For stormwater facilities for which the City will not provide long-term maintenance, the developer shall make arrangements with the existing or future (as appropriate) occupants or owners of the subject property for assumption of maintenance to the City's Stormwater Facilities Maintenance Manual as adopted by Clark County Chapter 13.26A. The City Engineer prior to City approval of the final stormwater plan shall approve such arrangements. Final plats shall specify the party(ies) responsible for long-term maintenance of stormwater facilities within the Plat notes for the subdivision or short plat.

The City may inspect privately maintained facilities for compliance with the City's requirements. If the parties responsible for long-term maintenance fail to maintain their facilities to acceptable standards, the City shall issue a written notice specifying required actions to be taken in order to bring the facilities into compliance. If these actions are not performed in a timely manner, the City shall take enforcement action and recover from parties responsible for the maintenance.

2. Easements Required. Easements or a covenant acceptable to the City Engineer shall be provided to the City for purposes of inspection of privately maintained facilities. The minimum dimensions of easements for stormwater facilities are as follows:
 - (i) Pond design and easements shall allow access to all areas within the pond and drainage structures by standard maintenance equipment vehicles;
 - (ii) Widths of easements for conveyance facilities shall be as detailed in the City standards.

CHAPTER 4
WASTEWATER COLLECTION

CHAPTER 4 - WASTEWATER COLLECTION

4.00 General Approval Requirements

- A. In the sewer service area, sewer main extensions are required to assure orderly and adequate extension of the sewer utility system. These extensions are to be in accordance with requirements of development and service availability as established by the City and the Washington State Department of Ecology.
- B. Design and construction of sewer mains and facilities, including but not limited to: sewer lift stations, telemetering facilities and appurtenances shall be in compliance with the latest edition of the City's ordinances, latest revision to the City's General Sewer Plan, these Standards, the Standard Details and the latest issue or revision of "Criteria for Sewage Work Design" published by the Washington State Department of Ecology.
- C. Sewer mains shall be extended through and to the extremes of the property being developed, to provide connection points for future development of unserved property as determined by the City.
- D. Side sewer permits for commercial and multifamily projects will be issued to owners as an extension agreement pre-construction requirement and shall be installed by a bonded contractor. The owner is required to make application and pay all necessary fees to obtain a permit. The side sewer can be installed as part of the mainline extension and put in use only after acceptance of the mainline system by the City. Side sewer permits for plats will be issued for installation only after main line extensions are accepted by the City. The lot owner or his bonded contractor is required to make application and pay all necessary fees, obtain a side sewer permit and connect the side sewer from the mainline lateral to the house plumbing.
- E. For multifamily residential developments, mobile home parks, RV parks, commercial facilities, and industrial facilities, public sewers shall be extended through easement to individual structures. For purpose of reducing infiltration, such extensions of public sewer shall be made to the limits of the roadway, parking access serving said buildings. Sewers shall be routed across pavement whenever possible. Each building shall be served by a lateral from the public sewer with a cleanout located in close proximity to the connection between the lateral and public sewer.

4.01 Planning Criteria

- A. Ensure adjacent properties can be provided sewer service (extend to extreme of property and designed for the ultimate development of the tributary areas).

Sewer service shall be provided by a gravity system (unless approved by the City Engineer).

In areas of the City where it is determined by the City Engineer that conventional gravity sanitary sewer service is not available, lift stations and forcemains may be

used upon approval of the City Engineer and Public Works Director. Grinder pumps may be used to serve individual lots that cannot flow by gravity into the sewer system upon approval of the City Engineer and Public Works Director.

B. Demand Projections

1. *Unit Demands:*

Residential - 100 gallons per capita per day (GPCD)

Commercial - Based on criteria found in Table G2-1 of the Department of Ecology Criteria for Sewage Works Design.

2. *Peaking Factors:*

Peaking factors shall be assigned to average day demands based upon criteria found in Figure C1-1 of the Department of Ecology Criteria for Sewage Works Design.

C. Infiltration/Inflow (I/I) Allowances

1. For new systems, I/I is accounted for in the projections and peaking factors developed using Department of Ecology criteria.

2. On existing sewer systems, I/I allowance shall be determined through a review of flow data from the existing system.

D. System Parameters

1. New sewer lines shall be designed so that under ultimate development peak flow, including I/I, shall not exceed 50% capacity of the line. Existing lines can have peak flows to 75% capacity of the line. Capacity analysis using an approved sewer model shall be conducted to verify sewer flows.

2. No connections to storm drainage system shall be made to the sanitary sewer system, unless approved by the City Engineer and only under special circumstances. (e.g. covered parking, wash down areas around garbage collection dumpster with an area less than 200 sq. ft.)

4.02 General Design Standards

A. Check that base map conforms to all requirements listed in the water and sewer utilities standard plan format per Chapter 1.

B. Check with City to determine how surrounding development will affect design (e.g. serve to extreme of property if adjacent property has potential for future development).

C. Cap end of existing sewer lines to be abandoned as follows:

1. Asbestos cement lines: use end cap coupling equal to ROMAC EC501.

2. Cast or ductile iron lines: use M.J. cap or plug

3. Clay or concrete lines: fill end of line with cement concrete minimum of 12 inches from end of line.

4. Plastic lines: use cap or plug fitting compatible with plastic pipe to be abandoned.
- D. Access shall be provided to every manhole and shall be appropriately sized for maintenance vehicles as determined by the City Engineer. In necessary locations as determined by the City Engineer, access to every other manhole may be provided.

4.03 Main Lines

- A. Minimum Pipe Size. Minimum sanitary sewer pipe size shall be 8 inches, unless meeting the criteria listed in the Department of Ecology Criteria for Sewage Works Design for using 6-inch pipe.
- B. Pipe Slope
 1. Minimum slope for sanitary sewer pipes shall be per Department of Ecology Criteria for Sewage Works Design Table C1-1, as required to obtain a 2 foot per second flushing velocity.
 2. Maximum main line slope shall not induce velocities greater than 10 feet per second under daily peak flows.
 3. Pipe anchor blocks shall be shown at 20 feet on center where pipe slope exceeds 20%.
- C. Horizontal Locations of Utilities
 1. Locate sewer mains in public right-of-way per City Standards.
 2. Outside of right-of-way, locate utilities in easements through paved areas wherever practical. Particular attention should be given to avoiding landscaped areas where trees may be planted.

4.04 Side Sewers

- A. For residential side sewers, 4-inch pipe shall be used for the side sewer from the main line to 8 feet past the edge of the property line. For commercial side sewers, 6-inch pipe shall be used for side sewer from main line to 8 feet past edge of property line (unless expected flows require larger size line).
- B. 4-inch minimum pipe shall be used for residential side sewers from the property line to the building. Commercial side sewers shall be a minimum 6-inch pipe.
- C. Side sewer shall have a minimum of 6 feet of cover at property line. Greater depths may be required where elevation of lowest floor to be served is lower than surface elevation at property line.
- D. All lots must be provided with their own side sewer. Provide a single stub to "low" end of each lot.
- E. Side sewers shall connect to main sewers with tee rather than a wye, unless otherwise approved by the City. On plan, indicate station of side sewer tee from

nearest downstream manhole. Also indicate length of side sewer from main to plug at end of 6-inch line.

- F. Minimum side sewer slope shall be two percent (2%) for 4-inch laterals and one percent (1%) for 6-inch laterals. Maximum slope shall be 100 percent.

4.05 Manholes

- A. Maximum length of main line between manholes shall be 400 feet.
- B. All manhole covers shall be set flush with ground surface, except where otherwise designated by the City Engineer. Manholes in easements shall have locking lids.
- C. Concrete perimeter seals shall be provided around all manhole adjustment sections in easement areas:
1. Paved areas- asphalt concrete per standard detail.
 2. Unpaved areas- cement concrete per standard detail.
- D. Terminal manholes (at end of main)
1. Side sewer stubs shall not connect to terminal manholes when there is a potential for future main line extension from manhole.
 2. Terminal manholes (without side sewer connection) shall not be channeled. Slope manhole base to provide positive drainage toward pipe, use 3,000 psi cement concrete.
- E. Where a side sewer connects to manhole, invert of side sewer shall be equal to or above main sewer crown, but not to exceed 18 inches above the invert of the main sewer.
- F. Drop in invert elevation across a manhole shall be from 0.1 ft to 0.2 ft. In areas with sewer main slopes less than 0.004 ft/ft, lesser drops are allowed, if approved by the City Engineer.
- G. Manhole Sizing
1. 48-inch diameter manhole
 - Up to 4 connecting pipes, 8-inch to 12-inch in diameter.
 2. 54-inch diameter manhole
 - 2 connecting pipes, 15-inch to 21-inch in diameter
 - 3 connecting pipes, 12-inch to 15-inch in diameter
 - 4 connecting pipes, 12-inch to 15-inch in diameter
 3. 72-inch diameter manhole
 - 2 connecting pipes, 21-inch to 24-inch in diameter
 - 3 connecting pipes, 15-inch in diameter
 - 4 connecting pipes, 15-inch in diameter

- i. The minimum angle between the incoming and the outgoing pipe shall be 90° unless otherwise approved by the City Engineer. Pipe shall be radial with the center of manhole.
 - ii. The above configurations shall provide adequate shelves and room for maintenance and performing T.V. inspections.
4. For other pipe configurations, the size of the manhole will be determined on a case by case basis.
- H. Any manhole less than 5 feet deep (rim to invert) shall be provided without a cone section. All other manholes shall be provided with an eccentric cone.
- I. Minimum manhole depths (invert to top of rim) shall be as follows:

Manhole Size	Pipe Size	Min Manhole Depth	Comments
48"	6"	3.0'	Special manhole per Std. Detail
	8"	3.2'	
	10"-12"	3.5'	
54"	8"	3.7'	Special manhole per Std. Detail
	10"-12"	4.0'	
	15"-18"	4.5'	
72"	15"	8.0'	Flat top manhole, 2 Access lids (one over each major pipe entrance/exit)
	18"-24"	8.5'	
	27"	9.0'	

- i. 72-inch manholes over 11.5 feet in depth shall include 48-inch reducing section per the standard detail.

4.06 Pipe Class / Protection / Cover

- A. Polyvinyl chloride (PVC) pipe class designation:
- 1. All sewer pipe shall be SDR 35 PVC conforming to ASTM D3034, unless otherwise determined by the City Engineer.
 - 2. Depth of cover over SDR 35 PVC pipe shall be 3 feet minimum and 20 feet maximum. Pipe depths outside this range will require use of pressure class PVC conforming to AWWA C900 (dimension ratio 18 or less).
 - 3. PVC pipe shall be encased in steel casing when crossing under rockeries or retaining walls. Casing to extend beyond footings or rockery face a minimum of 5 feet or the height of the wall or rockery, whichever is greater.
- B. Ductile iron pipe, class 52, shall be used where required by the City. Ductile iron sewer pipe shall be provided with a hydrogen sulfide resistant internal coating.
- C. All buried metal pipe shall be encased in 8-mil polyethylene per AWWA C-105, where required by the City.

- D. Building setback requirements:
1. 5 feet minimum from covered parking.
 2. 10 feet minimum from buildings and retaining walls, or equal to depth of pipe, whichever is greater.
 3. 20 feet minimum easement shall be provided between buildings.
 4. When passing between any two buildings (residential or commercial, etc.) which are 25 feet apart or less: the sewer line shall be oversized two (2) nominal pipe sizes above the capacity requirements between nearest manholes beyond limits of buildings.

4.07 Clearances / Other Utilities

- A. Water services and sewer stubs shall have at least 5 feet horizontal separation.
- B. Check for crossing or parallel utilities. Maintain minimum vertical and horizontal clearances. Avoid crossing at highly acute angles (smallest angle measure between utilities should be between 45 and 90 degrees).
- C. Horizontal clearances from sanitary sewer:
- | | |
|-----------|--------|
| Cable TV | 5 feet |
| Gas | 5 feet |
| Power | 5 feet |
| Storm | 5 feet |
| Telephone | 5 feet |

Vertical clearances from sanitary sewer:

Cable TV	1 feet
Gas	1 feet
Power	1 feet
Storm	1 feet
Telephone	1 feet

- D. Clearances between water and sanitary sewer mains shall be as follows:

Horizontal and Vertical Separation (Parallel)

A minimum horizontal separation of 10 feet between sanitary sewers and any existing potable water lines, and a minimum vertical separation of 18 inches between the bottom of the drinking water line and the crown of the sewer shall be maintained. The distance shall be measured edge to edge (i.e., from the outer diameter of the pipes.) as shown in Figure C1-2 in the Criteria for Sewage Works Design (rev. 10/2006).

Vertical Separation (Perpendicular)

Sewer lines crossing water lines at angles including perpendicular shall be laid below the water lines to provide a separation of at least 18 inches between the invert of the

water line and the crown of the sewer. In the event 18-inches of vertical separation cannot be achieved or the sewer line is required to be installed above the water line, the following is required.

Gravity Sewers Passing Under Water Lines

- Sewer pipe shall be encased in controlled density fill (CDF) with a minimum compressive strength of 300 psi or in a one quarter-inch thick continuous steel, ductile iron, or pressure rated PVC pipe with a dimension ratio (DR) of 18 or less, with all voids pressure-grouted with sand-cement grout or bentonite. Commercially available pipe skids and end seals are acceptable. When using steel or ductile iron casing, design consideration for corrosion protection should be considered. Encasement shall extend a minimum of 10-feet on each side of the crossing.
- One full length of sewer pipe shall be centered at the point of crossing so that the joints will be equidistant and as far as possible from the water line. The sewer pipe shall be the longest standard length available from the manufacturer.

Gravity Sewers Passing Over Water Lines

Water lines shall be protected by providing:

- A vertical separation of at least 18 inches between the invert of the sewer and the crown of the water line.
- Adequate structural support for the sewers to prevent excessive deflection of joints and settling on and breaking of the water lines.
- The length of sewer pipe shall be centered at the point of crossing so that the joints will be equidistant and as far a possible from the water line. The sewer pipe shall be the longest standard length available from the manufacturer.
- A water line encased in controlled density fill (CDF) with a minimum compressive strength of 300 psi or in a one quarter-inch thick continuous steel, ductile iron, or pressure rated PVC pipe with a dimension ratio (DR) of 18 or less, with all voids pressure-grouted with sand-cement grout or bentonite. Commercially available pipe skids and end seals are acceptable. When using steel or ductile iron casing, design consideration for corrosion protection should be considered. Encasement shall extend a minimum of 10-feet on each side of the crossing.

Pressure Sewers under Water Lines

- Pressure sewers shall be constructed only under water lines with pressure rated pipe encased in controlled density fill (CDF) with a minimum compressive strength of 300 psi or in a one quarter-inch thick continuous steel, ductile iron, or pressure rated PVC pipe with a dimension ratio (DR) of 18 or less, with all voids pressure-grouted with sand-cement grout or

bentonite. Commercially available pipe skirts and end seals are acceptable. When using steel or ductile iron casing, design consideration for corrosion protection should be considered. Encasement shall extend a minimum of 10-feet on each side of the crossing.

- E. The developer/contractor shall send a letter and preliminary plan to existing utilities to inform them of new construction and shall request as-built information for incorporation into plans. At a minimum the following utilities shall be contacted:
1. Cable television
 2. Natural gas
 3. Power
 4. Telephone

4.08 Connections to Existing Systems

- A. New sewer mains (8 inches and larger) shall connect to existing sewer main at existing manholes, or with new manhole on existing sewer per standard detail.
- B. Where new main is larger in diameter than existing downstream main, check that capacity of existing main is not exceeded by flow from new main.
- C. When connecting to existing manhole, check that requirements of Section 4.05K above are satisfied.
- D. If connecting to existing manhole which has access less than 24 inches in diameter and/or concentric cone (manholes over 5 feet deep), manhole shall be upgraded to include new 24-inch frame and cover and/or eccentric cone.
- E. Connections to end of existing pipe:
1. If end of pipe is known to have a bell and the new pipe is same material as existing, plans can specify connection by inserting spigot of new pipe into the existing bell end.
 2. If existing line is plain end, or must be cut, plans shall specify use of a coupling to connect new and existing lines.
- F. Approved couplings for use on sewer mains include:
1. Ductile iron mechanical couplings (equal to ROMAC) on ductile iron, concrete, or pipes with differing materials or diameters.
 2. On PVC or PE mains, PVC or PE couplings with compatible dimension ratio and gaskets to connect new and existing pipes shall be used.

4.09 Fats, Oils, Grease Separation

- A. Oil/water separator. Whenever an industrial or commercial business generates mineral/petroleum oils exceeding 100 milligrams per liter to be discharged to the

sanitary sewer, pre-treatment is required. An oil/water separation device shall be installed by the property owner as specified on various standard details. Selection and sizing of an oil/water separator shall be subject to approval of the City Engineer. Water discharged from any oil/water separator to the sanitary sewer system shall not contain in excess of 100 milligrams per liter of petroleum oil, non- biodegradable cutting oil or mineral products to be in compliance with the City of Ridgefield Regulations for Discharge to the Sanitary Sewer.

1. The oil/water separator shall be owned and maintained by the property owner. The property owner shall make the oil/water separator available for inspection by City public works staff at any time. A proposed maintenance schedule for the oil/water separator shall be submitted with the design plans.
 2. Sizing of a separator facility shall be based upon maximum available flow to the separator and provision of a forty-five minute retention time in the separator at that flow, with a minimum capacity of at least 450 gallons.
 3. The oil/water separator shall be covered with removable sections and provided with access and inspection covers, weighing not more than 30 lbs. The oil/water separator will be provided with suitable hand holds, are to be provided directly above inspection "tee" and oil/grit collection compartments.
 4. Only waste water from floor drains and covered parking garages shall drain to the separator. The location and design shall minimize or eliminate the possibility of storm water reaching the separator -- areas over two hundred square feet open to rainfall shall not drain to the separator. Sewage from restrooms and shower facilities shall not drain to the separator. See standard detail.
 5. Allowable materials for construction are as follows:
 - Tank - concrete
 - Baffles - concrete, steel plate
 6. The separator shall be located within 20 feet of drive for access by maintenance vehicle.
 7. A sampling tee shall be located on the outlet with a minimum 18 inch drop below the invert. Access to the separator shall be maintained free for inspection and compliance determination sampling at all times.
 8. The effluent discharged from any oil/water separator to the sanitary sewer shall not exceed 100 parts per million total oil.
 9. When pre-treatment is no longer required, the inlet and outlet pipes shall be permanently plugged, the separation chambers pumped out, and the vault removed.
- B. Grease interceptor. Whenever a commercial and/or retail food preparation operation, regardless of size, generates animal/vegetable fats, oils or grease (f.o.g.)

waste in excess of 100 milligrams per liter to be discharged to the sanitary sewer, pre-treatment is required. A grease interception device shall be installed by the owner as specified on various City of Ridgefield Standard Details. Effluent discharged from any grease interceptor shall contain no more than 100 milligrams per liter animal/vegetable f.o.g. and be in compliance with the City of Ridgefield regulations for discharge to the sanitary sewer.

1. The grease interceptor shall be owned and maintained by the property owner. The property owner shall make the grease interceptor available for inspection by City public works staff at any time. A proposed maintenance schedule for the grease interceptor shall be submitted with the design plans.
2. Size and design of the grease interceptor shall conform to the Uniform Plumbing Code, Appendix H Standards, and shall be subject to approval by the City. Minimum capacity shall be 1,500 gallons except as noted by the City of Ridgefield.
3. Fixtures in the kitchen area which discharge waste-water containing grease are to be connected to the grease interceptor. Such fixtures include dishwashers, pot sinks, range woks, janitor's sink, floor sinks, rotoclones, toilets, urinals, and wash basins shall not flow through the interceptor.
4. The interceptor shall be located exterior to the building within twenty (20) feet of drive for access by maintenance vehicles.
5. The interceptor shall be filled with clean water prior to start-up of system. Allowable materials for construction are as follows:
 - Tank - concrete
 - Baffles - concrete, plastic
6. Access to the interceptor shall be maintained free for inspection and compliance determination sampling at all times.
7. When pre-treatment is no longer required, the inlet and outlet pipes shall be permanently plugged, the separation chambers pumped out, and the vault removed.

4.10 Easements

- A. Show easements off roadways and identify width.
- B. Show easements on developer's property. If easement is defined as a constant width on each side of sewer main, then show a segment of the easement and label as typical (typ).
- C. All easements shall be a minimum of 15 feet in width, unless otherwise approved or required by the City Engineer.

4.11 Pump Stations

- A. Pump stations shall only serve those properties which cannot otherwise be served by conventional gravity sewers.
- B. Pump stations shall be approved on an individual basis by the City. Prior to construction, the City must review and approve submittals for all materials and equipment.
- C. Pump stations shall generally be designed in conformance with Chapter 9 of the June 2007 edition of the Clean Water Services “Design and Construction Standards for Sanitary Sewer Service and Surface Water Management” manual and the Washington State Department of Ecology Regulations and Requirements, except as herein modified.
- D. Pump stations shall be furnished with provisions for emergency power with 48 hours fuel capacity. Emergency generators shall be powered by diesel engines, if possible and shall be provided with noise attenuating enclosures. The developer shall submit to the City Engineer evidence of permit application and fee payment to the Southwest Clean Air Agency, Vancouver office, for any emergency generator prior to final acceptance of construction.
- E. Submersible pump stations shall be provided with Flygt pumps or equal and shall be 460 volt 3-phase. One pump shall be equipped with a Flygt pump flushing valve.
- F. Electrical panels mounted in unprotected areas will not be allowed. As a minimum, panels shall be located under a shed roof extending three (3) feet in all directions from the edges of the panel. The electrical and/or signal cables entering the wet well shall have water tight connections capable of cable disconnect.
- G. All pump station sites shall have a paved 15 feet wide service road and shall be security fenced with a lockable gate.
- H. All pump stations shall be provided with a 1-inch potable water service including reduced pressure backflow preventor and frost free yard hydrant.
- I. All pump stations shall be equipped with City approved telemetry. Control and telemetry systems shall use Allen Bradley PLCs. Controls shall include hardwired high level alarm floats and back-up pump down timers. Control panels shall be designed based upon the City of Ridgefield standard control schematic.
- J. Radio telemetry shall be used if adequate signal is available. It is the responsibility of the developer to evaluate the adequacy of radio telemetry for each site. If radio telemetry is not available for the site, telephone telemetry may be used.
- K. The developer shall pay all costs for the City’s telemetry integrator to develop a new SCADA screen for the lift station at the City’s master SCADA system. It shall be the developer’s responsibility to ensure that the lift station telemetry system communicates with the City’s master telemetry system.

- L. Control of pump stations shall be by Multitrode Liquid Level Control Probes and backup floats or other means acceptable to the City Engineer. Each lift station shall be provided with a minimum of the following floats:
- High level alarm
 - Lag pump on
 - Lead pump on
 - All pumps off
 - Low level alarm
- M. Each pump station shall be provided with a means for hydrogen sulfide control using one of the following methods:
- Calcium Nitrate Injection (Bioxide)
 - Liquid Oxygen Injection
- The developer shall evaluate the alternatives for the pump station based upon the hydraulics, forcemain profile, and flow conditions. The City Engineer shall approve the method used.
- N. Each pump station must be provided with a means for cleaning the sewer forcemain including pig launching and pig retrieval stations. Contractor shall be required to provide one new plastic coated pig to the City.
- O. Isolation valves in lift stations shall be full port eccentric plug valves with resilient seat and handwheel operators. Each pump shall be provided with a Red Valve Pressure Sensor, or equal on its discharge piping. Gauges on the pressure sensors must be visible and readable from the vault hatch.
- P. All exposed pump station piping and valve in the wet well or valve vaults must be painted with an epoxy painting system (Tnemec Series 66/69 or equal).
- Q. Each pump station shall be provided with lifting equipment including hoist and socket for removing pumps.
- R. All forcemains shall be installed with a continuous insulated 12 gauge solid copper toning wire.
- S. Access hatches shall be watertight aluminum hatches rated for H-20 loading with spring assist and locking hasp, and safety grate, as manufactured by Halliday Products or equal.
- T. Each pump station shall be provided with a magnetic flowmeter as manufacture by Siemens or approved equal. Indicator/transmitter shall be mounted at the control panel and the flowmeter shall be provided with a submergence kit.
- U. All fasteners, bolts nuts, etc. located inside wet wells and vaults shall be stainless steel.

4.12 Grinder Pump System

- A. Individual lots that cannot be served by gravity sewer service may be provided with Grinder Pump Systems, if approved by the City Engineer.
- B. Grinder pump systems shall be engineered positive displacement systems, E/One or equal, with a minimum storage tank capacity of 225 gallons. Lots served by grinder pumps must include a statement on the face of the plat indicating that operation and maintenance of the grinder pumps is the responsibility of the home owner.

CHAPTER 5

WATER

CHAPTER 5 - WATER

5.00 General Approval Requirements

- A. In the City's water service area, watermain extensions are required to assure orderly and adequate extension of the water utility system. These extensions are to be in accordance with requirements of development and service availability as established by the City and the Washington State Department of Health.
- B. Water mains shall be extended to the limits of the property being served for service to adjacent parcels where directed by the City Engineer.
- C. For multifamily residential developments, mobile home parks, RV parks, commercial facilities, and industrial facilities, public water mains shall be extended through easement to individual structures. For purpose of reducing potential water quality problems, such extensions of public water shall be made to the limits of the roadway, parking access serving said buildings. Water mains shall be routed across pavement whenever possible. Each building shall be served by a separate water meter from the public water main.

5.01 Planning Criteria

- A. Ensure adjacent properties can be provided water service (extend to extreme of property with adequate capacity and pressure).
- B. Demand projections:
 1. Unit demand, Average daily demand (ADD):
 - a. Single family residential - 160 gallons per capita per day (GPCD), or 400 gallons per day per Equivalent Residential Unit
 - b. Multi-family residential - 80 GPCD
 - c. Nonresidential – Use WSDOH Water System Design Manual Table 5-2
 2. Peaking factors:
 - a. Maximum day demand (MDD) = $ADD \times 2.4$
 - b. Peak Hour Demand = Use WSDOH Water System Design Manual Equation 5-3.
- C. System parameters:
 1. Water velocity in mains - velocities shall not exceed 10 feet per second during highest demand and fire flow.
 2. Distribution system pressures (measured at building elevation):
Desirable- Minimum 50 psi
Maximum 80 psi
Allowable-Minimum 40 psi
Maximum 100 psi

- * Pressure reducing valves are required on all services when water pressure exceeds 80 psi. Pressure reducing valves shall be installed on main lines rather than individual services unless otherwise directed by the City Engineer.
 - 3. Reservoir replenishment - facilities (e.g., transmission mains, pump stations) shall be sized to enable storage facilities to be refilled within 3 days after an emergency or major fire.
- D. Fire flow requirements shall be as determined by the Clark County Fire Marshal.
- 1. Determination of available fire flow shall be computed using a computer simulated model acceptable to the City with a base demand equal to the maximum daily demand.
 - 2. Minimum system pressure during fire flow analysis shall be 20 psi at all hydrants and throughout the water system.

5.02 General Design Standards

- A. Check that base map conforms to all requirements listed in the water and sewer utilities standard plan format per Chapter 1.
- B. Thrust Restraint
- 1. All thrust restraint for waterlines shall be accomplished through the use of restrained joints.
 - a. Restrained joints for pipe shall be appropriately designed for the required test pressure. The following is an approved list of restrained joint systems:
 - i. LOC TYTE and MJ-TJ pipe with Megalugs, Pacific States Cast Iron Pipe Company
 - ii. Fast Grip and Lok Ring, American Cast Iron Pipe Company
 - iii. TR Flex and Field Lok, United States Pipe and Foundry Company
 - iv. Snap Lock, Griffin Pipe Products Company
 - v. Megalug, EBAA Iron, Inc.
 - vi. Super Lock, Clow
 - vii. Restrained Joint, McWane
 - 2. Collar thrust blocks or other special blocking designs may be used if necessary. Show all blocking on plans and profiles.
 - 3. A restraint table shall be provided in the plan set for the pipe size and fittings used.
- C. Check with City Engineer to determine how surrounding development will affect design:
- 1. Serve to extreme of property if adjacent property has potential for future development.

2. All systems shall be looped systems where possible..
 3. Where dead end lines cannot practically be avoided as determined by the City Engineer, a permanent blow off capable of providing a 2.5 fps flushing velocity shall be provided along with provisions as needed for disposal of flushing water.
- D. To assure compatibility with existing system, check with City Engineer to determine hydraulic gradients.
- E. Cap end of existing water lines to be abandoned as follows:
1. Asbestos cement lines: use end cap coupling and thrust blocking.
 2. Cast or ductile iron lines: Use M.J. cap or plug and thrust blocking.
- F. Minimum watermain size
1. 8-inch minimum diameter when serving fire hydrants.
 2. 6-inch minimum diameter may be used in localized conditions where fire hydrants are served by looped lines, subject to City Engineer approval.
- G. One below grade sampling station shall be provided for every one-hundred (100) lots developed. All subdivisions with more than fifty (50) lots shall install a sampling station. The sampling station shall be installed in a meter box from a dedicated water service. Sampling station shall be a USA Blue Book Model 1500, or equal.
- H. No lengths of ductile iron pipe less than 3 feet in length will be allowed to be installed with the exception of valve and tee/cross connections.
- I. Local high points and local low points shall be avoided whenever possible. Blow-off assemblies and air release valves shall be installed where necessary at low and high points in watermain to allow for removal of sediments and release of air.

5.03 Valving

- A. 500 feet maximum distance between valves on distribution mains. Long transmission mains with limited services may provide isolation valves at 1,000 foot spacing with the approval of the City Engineer.
- B. Provide valve at both ends of an easement.
- C. Valves shall be placed at all legs of watermain intersections, unless otherwise indicated by the City.
- D. Additional valving may be required for area isolation.
- E. Valves 12 inches and smaller shall be gate valves.
- F. Valves 14 inches and greater shall be butterfly valves.
- G. An in-line valve with appropriate restraint shall be placed at all temporary dead-ends that are likely to be extended in the future to facilitate future connection.

5.04 Fire Hydrants

- A. The number and locations of fire hydrants, fire flow requirements and fire sprinkler components will be determined by the City, Clark County Fire Marshal, or Clark County Fire District 12. Following are general requirements for fire hydrant locations: (These criteria are subject to change. For the most current information, contact the Fire Marshal's office.)
1. **Commercial Buildings:** Fire hydrants shall be located so that no part of a commercial building is more than 250 feet from a fire hydrant measured along a route accessible to fire department vehicles. When a fire department connection (FDC) is installed in conjunction with an automatic sprinkler system, it is required to have a fire hydrant located within 40 feet of the FDC. The FDC shall be located remote from the building and outside of the building collapse zone. This area should be clearly marked "Fire Zone No Parking". No building access road can be blocked by fire hose while making the fire department connection.
 2. **Non-Commercial Buildings** Unless otherwise approved by the Fire Marshal, a fire hydrant shall be placed at each street intersection, or at spacing not exceeding 600 feet. Intermediate hydrants are required when the distances to any part of noncommercial buildings exceeds 500 feet measured along a route accessible to fire department vehicles.
- B. Fire hydrants shall not be connected to mains less than 8 inches, or 6 inches in diameter where the length of the 6-inch main is less than 50 feet.
- C. Fireline/hydrant run over 50 feet in length must be 8 inches in diameter (terminate with tee, plug and hydrant assembly).
- D. Hydrant shall be located minimum 50 feet from any building, unless approved by the Fire Marshall.
- E. As per the IFC, fire hydrants shall be located to allow a 36-inch clear space surrounding the hydrant. For example, street lights, sign posts, protective posts, or retaining walls shall be no closer than 36 inches from the nearest portion of a hydrant. There shall also be no obstructions directly in line with any of the ports of the hydrant.
- F. Piping between fire sprinkler vaults and protected building shall not be shown on water design.
- G. Guard posts are to be used only in parking lots when no curbs are present or in exposed areas in parking lots.

5.05 Pipe Class / Protection / Cover

- A. All waterlines shall be ductile iron pipe Class 52 unless otherwise noted herein. When crossing under rockeries and retaining walls, pipe shall be installed in a steel casing that extends beyond the footings or rockery face a minimum of 5 feet and

extends beyond the back of rockery or wall equal to the height of the wall or rockery or a minimum of 5 feet.

- B. Watermain depth of cover shall be 3 feet minimum and 6 feet maximum from final grade.
- C. Building setback requirements:
- 5 feet minimum from covered parking to watermain.
 - 10 feet minimum from building (and retaining walls) to watermain.
 - 20 feet minimum easement shall be provided between buildings.

When passing between single family residential buildings which are 25 feet apart or less, Class 53 ductile iron pipe shall be used to a point 5 feet beyond the limits of building.

When passing between commercial or multifamily buildings which are 25 feet apart or less, the waterline shall be encased in steel pipe. The casing shall be wrapped with polyethylene as per City standards. The line shall be encased to a point 5 feet beyond the limits of the building.

- D. All ductile iron pipe and adjacent fittings shall be encased in 8-mil polyethylene per AWWA C-105 when crossing gas lines or paralleling within 5 feet where directed by the City Engineer.

5.06 Clearances / Other Utilities

- A. See Section 4.07.E for separations between water and sanitary sewer lines.
- B. Check for crossing or parallel utilities. Maintain minimum vertical and horizontal clearances. Avoid crossing at highly acute angles (smallest angle measure between utilities should be between 45 and 90 degrees).
- C. At points where thrust blocking is required, minimum clearance between the concrete blocking and other buried utilities or structures shall be 5 feet.

- D. Horizontal clearances from watermain:

Cable TV	5 feet
Gas	5 feet
Power	5 feet
Storm	5 feet
Telephone	5 feet

- E. Vertical clearances from watermain:

Cable TV	1 foot
Gas	1 foot
Power	1 foot
Storm	1 foot

Telephone 1 foot

- F. The developer/contractor is responsible for sending a letter and preliminary plan to existing utilities to inform them of new construction and requesting as-built information for incorporation into plans. At a minimum the following utilities shall be contacted:

Cable television
Natural gas
Power
Telephone

5.07 Slopes

- A. Vertical bends shall be used when joint deflection would exceed 3 degrees.
B. All pipe joints shall be restrained where slopes are 20% or greater. Anchor blocks shall be used in conjunction with joint restraint where slopes are 25% or greater.

5.08 Connections to Existing System

- A. When tapping water mains, use stainless steel full booted tees conforming to 18-8 Type 304 stainless steel with a CF 8 cast stainless steel flanged end with ANSI 150 lb drilling. Bolts and hardware shall be Type 304 stainless steel. B. Connections to existing mains 8-inch diameter and larger shall be via a wet tap unless otherwise approved by the City.
C. Connections to existing mains smaller than 8-inches in diameter shall be by cutting in a tee, unless otherwise approved by the City Engineer.
D. Size on size tapping tees are not allowed unless otherwise approved by the City Engineer.

5.09 Easements

- A. Show all utility easements and identify width. If easement is defined as a constant width on each side of watermain, then show a segment of the easement and label as typical (typ).
B. All easements shall be a minimum of 15 foot in width, unless otherwise approved or required by the City Engineer.

5.10 Services

- A. Locate water services and indicate size. Sizes shall be determined by the developer and approved by the City Engineer.
B. For offices, multi-family developments and plats with planter areas, provide irrigation services.

- C. Irrigation shall be by separate water main connection and service unless approved by the Public Works Director. Deduct meters may be allowed for commercial/industrial development.
- D. Static service pressures at ground floor elevation shall be determined at all lots/buildings to ensure compliance with system pressure standards.
- E. Plan shall identify lots/buildings where builder/owner should install individual pressure reducing valves. Individual service PRVs are required on customer side of service lines (after water meter box) when service pressures exceed 80 psi.
- F. Meter boxes shall be located within the right-of-way inside the corresponding property lines for the lot being served unless otherwise noted.

5.11 Backflow Prevention

A. Private fire protection systems shall comply with minimum backflow requirements as outlined in the following charts on the following page or as determined by the Clark County Fire Marshall's Office or Clark County Fire District 12. .

B. Irrigation and special domestic services, because of the varying degrees of hazard shall comply with minimum backflow requirements as outlined below. Some of the concerns with these systems are:

1. The growth of offensive micro-organisms which can create taste and odor problems.
2. The leaching of heavy metals such as zinc, cadmium, iron, or lead into the water.
3. The addition of corrosion inhibitors or antifreeze compounds to protect the piping system.
4. A loss of pressure on the public water supply main or an increase in pressure on the user's system which would reverse the water flow into the public supply.

C. Installation shall comply with the City of Ridgefield requirements and regulations as approved by the State of Washington, Department of Health.

D. All private fire systems such as double check valve assemblies from the mainline control gate valve shall be owned and maintained by the property owner.

E. All backflow preventers shall be installed in vaults outside of building as close as possible to supplying main.

F. Fire systems in existing buildings being revised or upgraded shall comply with current regulations.

- G. Special "health hazard" facilities (facilities named in cross-connection control W.A.C. 248-54-285) such as hospitals, morgues, wastewater plants, metal plating facilities, laboratories, and food beverage plants, usually contain water connections that could backflow hazardous materials into the potable water supply. Therefore, these types of facilities are required to have backflow prevention devices as noted on the chart on the following page.

Private Firelines and Fire Sprinkler System Chart

	Double Check Valve Assembly	Double Check Valve Assembly with Detector	Reduced Pressure Backflow Assembly	Reduced Pressure Backflow Assembly with Detector
1. Fire system - (without chemical addition) 3-inch & larger		X		
2. Fire system - (without chemical addition) 3/4-inch to 2-1/2-inch	X			
3. Private fire system with hydrants		X		
4. Fire system - (with chemical addition) 3-inch & larger				X
5. Fire system - (with chemical addition) 3/4-inch to 2 1/2-inch				X

Notes:

1. All backflow prevention assemblies require test and inspection at the time of installation and annual test thereafter.
2. Backflow assemblies shall be installed per the standards details.

Irrigation and Domestic Service Backflow Protection Chart

	Double Check Valve Assembly	Reduced Pressure Backflow Assembly	Double Check Valve Assembly and by-Pass
1. Irrigation system - (without chemical injection)	X		
2. Irrigation systems - (with chemical injection)		X	
3. Tall buildings - over 30 feet above ground level <u>or</u> with in-line booster pump interrupted service permissible	X		
4. Tall building - over 30 feet above ground level <u>or</u> with in-line booster pump uninterrupted service required			X

5. Facilities with health hazards, i.e., hospitals, laboratories, sewage lift stations, car washes etc.**		X	
-----------------------------------------------------------------------------------------------------------	--	---	--

Notes:

1. All backflow prevention assemblies require test and inspection at the time of installation and annual test thereafter.
2. Backflow assemblies shall be installed per the standards details.
3. If service is uninterruptable, then bypass with RPBD is required.

5.12 Reclaimed Water Systems

- A. Applicability. It is the City's policy to require that all reclaimed water systems meet applicable state standards for the distribution and use of reclaimed water. Where reclaimed water is available for use, the City may require that this water source be given preference as a substitute for non-potable water or irrigation use. Where reclaimed water systems are authorized or required by the City, they shall be designed per Washington State Department of Ecology standards.